

Technical Comments on Electric Generating Unit Control Technology Options and
Emission Allocations Proposed by the Environmental Protection Agency
in Support of
the Proposed 2015 Ozone NAAQS Transport Rule

Prepared by

J. Edward Cichanowicz
Consultant
Saratoga, CA

James Marchetti
Consultant
Washington, DC

Michael C. Hein
Hein Analytics, LLC
Whitefish, MT

Shirley Rivera
R-CAT
Union City, CA

Prepared for the

Midwest Ozone Group
National Rural Electric Cooperative Association
American Public Power Association

June 17, 2022

Table of Contents

1. Summary of Flaws in EPA’s Approach	1
2. Introduction.....	3
3. Generating Unit Inventory	4
3.1 Inventory: This Study	4
3.2 Inventory: Units without SCR	5
3.3 Inventory: Units with SCR	6
4. Combustion Control Capability	8
4.1 Introduction.....	8
4.2 Referenced Units	8
4.2.1 Tangential-Fired Boilers.....	10
4.2.2 Wall-Fired Boilers	10
4.3 Generalizing Results to Boiler Population.....	12
4.3.1 Fuel Composition	12
4.3.2 Boiler Design	12
4.3.1 Owner Experience	14
4.4 Revised Control Capability, Cost.....	15
4.5 Installation Schedule.....	16
5. POSTCOMBUSTION NO_x CONTROL	18
5.1 Selective Catalytic Reduction (SCR)	18
5.1.1 Performance Basis	18
5.1.2 Cost Basis	19
5.2 Selective Non-Catalytic Reduction (SNCR)	22
5.2.1 Performance Basis	22
5.2.2 Cost Basis.....	23
5.3 Installation Schedule.....	24
6. Cost Evaluation Results: NO_x Control Cost per Ton for Ozone Mitigation	27
6.1 Units without SCR: Retrofit	27
6.1.1 Coal-Fired Duty	27
6.1.2 Distillate Oil/Natural Gas	29
6.2 SNCR Retrofit	32
6.3 Existing SCR Performance.....	33
6.4 Postcombustion NO _x Takeaway	34
7. Proposed Backstop Daily NO_x Rate	35
7.1 Background: Startup	35
7.2 2021 Inventory Data	38
7.3 Takeaway.....	43
8. Generation Shifting.....	44
8.1 Overview of Findings.....	45
8.2 Arkansas	47
8.3 Indiana.....	48
8.4 Kentucky.....	49
8.5 Missouri.....	49

8.6	Ohio.....	50
8.7	Pennsylvania.....	51
8.8	Texas	52
8.9	West Virginia	54
8.10	Wyoming	55
9.	State Budgets, Emissions Allocations, and Reliability	57
9.1	State Budget Setting Process.....	57
9.1.1	Identification of Errors and Omissions	57
9.1.2	Technology Assignment Issues	58
9.1.3	Technology Deployment Issues	59
9.1.4	Recalculation of State Budgets	60
9.1.5	Non-SCR Unit Retirements between 2026 and 2030	62
9.1.6	2021 Baseline.....	62
9.2	Emission Allowances and Reliability.....	62
Appendix A: State Maps		66
Appendix B: Summary of Planned Retirements- 2026-2030		71

List of Tables

Table 3-1.	Inventory of Units Considered for SCR Retrofit: Coal and Oil/Gas Fired	6
Table 3-2.	Inventory of Units Equipped With SCR: Coal and Oil/Gas Fired	7
Table 4-1.	Average Achievable NOx Emissions Rates	15
Table 4-2.	Combustion Control System Acquisition, Installation Time	17
Table 7-1.	Units, Exceedances of Exceeding Proposed Backstop Rate of 0.14 lbs/MBtu	43
Table 8-1.	IPM 2023 Retired and Idled Coal Capacity in the Nine-State Study Region (MW) ..	46
Table 8-2.	Allowances Lost to Generation Shifting in 2023	56
Table 9-1.	2021 Unit Emission SCR Emission Rates (lbs/MBtu).....	57
Table 9-2.	Natural Conversions in the Nine State Study Area	58
Table 9-3.	Retirement Date Changes in the Nine State Study Area	58
Table 9-4.	Technology Assignment Issues in the Nine State Study Area	59
Table 9-5.	Average Achievable NOx Emission Rates (lbs/MBtu).....	60
Table 9-6.	Recalculated State Optimized Baselines: 2023 and 2026	61
Table 9-7.	2023 Generation Shifting Discrepancies	61
Table 9-8.	EGU 2023 Ozone Season Emission and Allocations by State	63
Table 9-9.	Electric Generating Unit 2026 Ozone Season Emissions and Allocations	63

List of Figures

Figure 3-1. Inventory of Boilers in the 25 State Region.....	4
Figure 3-2. Inventory of Boilers in the 25 State Region.....	5
Figure 4-1. 2021 Average Ozone Season NO _x Emissions: Tangential-Fired Boilers Firing Bituminous, Subbituminous, Blends and Lignite Coals	9
Figure 4-2. 2021 Average Ozone Season NO _x Emissions: Wall-Fired Boilers Firing Bituminous, Subbituminous, Blends and Lignite Coals.....	9
Figure 4-3. Definition of Burner Zone Liberation Rate: Four Major Boiler Suppliers	13
Figure 4-4. Wall-Fired Boiler Experience with Evolving Low NO _x Burner Technology	14
Figure 5-1. Capital Cost vs Capacity Relationship for SCR NO _x Control: Coal and Distillate Oil/Natural Gas	20
Figure 5-2. Ash Deposition on Catalyst Impeding NO _x Removal Performance	22
Figure 5-3. Capital Cost vs Capacity Relationship for SNCR NO _x Control: Coal and Distillate Oil/Natural Gas	24
Figure 5-4. Timeline for Engineering, Procurement, and Installation of SCR Postcombustion Control Technology	25
Figure 5-5. Capacity (MW Basis) of SCR Retrofits Since 1994	26
Figure 6-1. SCR Retrofit to Coal-Fired Units: Incurred Cost per Ton, 10-Year Basis	28
Figure 6-2. SCR Retrofit to Coal-Fired Units: Incurred Cost per Ton, 5-Year Basis	28
Figure 6-3. NO _x Removal cost per SCR Retrofit: Role of Boiler Exit NO _x Rate	30
Figure 6-4. SCR Retrofit to Oil/Gas-Fired Units: Incurred Cost per Ton, 10-Year Basis	31
Figure 6-5. SCR Retrofit to Oil/Gas-Fired Units: Incurred Cost per Ton, 5-Year Basis	31
Figure 6-6. SNCR Retrofit to Coal-Fired Units: Incurred Cost per Ton, 10-Year Basis	32
Figure 6-7. Incurred Cost per Existing SCR to Achieve 0.08 lbs/MBtu	33
Figure 7-1. Timeline of Key Events in SCR Process Startup	36
Figure 7-2. LG&E/KU Mill Creek Unit 4 Startup Data	36
Figure 7-3. LG&E/KU Trimble County 2: Time Duration of SCR Startup Events	37
Figure 7-4. Count of Units Emitting Above Proposed Backstop Rate	39
Figure 7-5. Role of Startup days on Count of Units Emitting Above Proposed Backstop Rate ..	39
Figure 7-6. Count of Units Experiencing at Least One Hour of Outage	40
Figure 7-7. Role of Days Following Startup on Days Exceeding Daily Rate	40
Figure 7-8. Role of Load Factor	42
Figure 8-1. IPM Model: Definition of 67 Modeling Regions.....	45
Figure 8-2. Generation Shifting Summary: Arkansas.....	47
Figure 8-3. Generation Shifting Summary: Indiana	48
Figure 8-4. Generation Shifting Summary: Kentucky.....	49
Figure 8-5. Generation Shifting Summary: Missouri	50
Figure 8-6. Generation Shifting Summary: Ohio	51
Figure 8-7. Generation Shifting Summary: Pennsylvania	52
Figure 8-8. Generation Shifting Summary: Texas.....	53
Figure 8-9. Generation Shifting Summary: Texas, ERCOT.....	53
Figure 8-10. Generation Shifting Summary: Texas, Non-ERCOT.....	54
Figure 8-11. Generation Shifting Summary: West Virginia.....	55
Figure 8-12. Generation Shifting Summary: Wyoming	56

1. Summary of Flaws in EPA's Approach

The following is an abbreviated summary of flaws in EPA's analysis that are described in detail in the remainder of this report.

Cost Premises. EPA errs in assuming units to be retrofit with SCR will operate for 10 years, and does not adequately escalate cost from a 2021-dollar basis.

- EPA, by using a capital recovery factor of 0.142, implies a 10-year life for recovery of SCR capital cost, which lowers the calculated incurred cost per ton (\$/ton) of NO_x removed. It is possible that generating units will terminate operation before then. The cost incurred (\$/ton basis) for a 5-year lifetime is shown in this report to be as much as double the cost incurred for a 10-year recovery.
- EPA adopts the Sargent & Lundy (S&L) cost premises to escalate costs from 2011 at 2.5% annually to 2021. The S&L cost methodology does not reflect the recent changes in material and labor cost which are continually evolving. The analysis in this report adopted S&L's approach through 2019, then employed the Chemical Engineering Equipment Cost Index (CEPCI) for escalation from 2019 through mid-2021.

Optimistic Control Capability of Advanced Combustion NO_x Controls. EPA projects the achievable NO_x emissions rate (lbs/MBtu basis) to the national fleet based on extrapolating NO_x emission reductions achieved from select operating units, without proper regard for the role of fuel rank, fuel composition, and fuel variability, as well as furnace geometry in generalizing results.

Unrealistic Timeline Schedule for Retrofit of Combustion and SCR NO_x Controls. EPA's assumption of less than 12 months as necessary for combustion control retrofit is unrealistic, and not supported by detailed submittals for 11 authentic recent installations. Similarly, EPA's assumption of a timeline supporting retrofit of SCR to approximately 100 units in less than 36 months is unrealistic, and not supported by authentic experience for 25 recent installations. Industry experience as detailed in this report suggests that 60 months may be appropriate to enable most units to deploy SCR.

Incorrect Cost Metric for Existing SCR-equipped Units. For units presently equipped with SCR, the proposed rule extracts incremental reductions in NO_x from the baseline of 2021 emissions – but does not calculate the increment in cost exclusively for this action. Rather, EPA presents a “revisionist” cost of the initial SCR NO_x retrofit project, determining the cost to achieve 0.08 lbs/MBtu from the historical boiler NO_x rate. The metric EPA uses is incorrect, as it blends the control cost for the present action with the initial decision to deploy SCR, lowering the apparent cost.

Inaccurate Capital, Operating Cost for SCR Retrofit. The capital charge is to be adjusted to reflect a rationale number of installations that will employ and Engineer Procure Construct (EPC) approach, and (b) properly account for catalyst management costs for high-performing applications.

Daily Backstop Rate. EPA's daily backstop rate of 0.14 lbs/MBtu, as presently proposed, will penalize even well-run SCR processes, as NOx emissions emerging from startup show the proposed rule will prompt for even well-run units some operating days above this rate. The analysis in this report shows any unit undergoing a startup will unavoidably exceed the rate as proposed. Further, an owner – by avoiding a shutdown to repair a malfunction – could compromise the ability to meet a targeted SCR exit rate, in order to avoid exceeding the backstop rate.

Grid Operability May Not Support Generation Shifting. EPA's introduction of generation shifting as a "control step" is unrealistic. EPA assumes there are no barriers to the movement of power within a state, when in fact the design and operation of the power delivery grid frequently dictates movement of energy. Further, some of the energy EPA requires to be shifted within a state must cross boundaries of more than one Regional Transmission Operators (RTO), comprising an energy transfer rarely executed. This need to support grid reliability is even more important as new generation sources evolve, and both renewable and natural gas fired combined cycle generation in planned and constructed.

EPA Needs to Revise the State Budgets. Due to omissions and errors, the state budgets calculated by EPA need to be revised, in order to prevent reliability concerns beginning in 2023. Some provision that comprises a "reliability off-ramp" should be included that allows unit operation without the requisite allowances, when grid reliability is challenged.

Generation Shifting Step in the State Budget Setting Process Should be Eliminated. The basis of this step is flawed. The Base Case used in the Generation Shifting modeling is inaccurate and leads to erroneous modeling results.

2. Introduction

The Environmental Protection Agency (EPA) proposal for a revised Federal Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standard (Cross-State Air Pollution Rule for the 2015 Ozone NAAQS) is premised on cost and performance capabilities of NO_x emission control technology. EPA claims to have considered realistic assumptions defining NO_x control capabilities and cost in their analysis. These assumptions are reported by EPA in the Technical Support Document (TSD)¹ where EPA presents costs, emission reduction potential, and their assessment of feasibility related to the emission control strategies.

Many of these assumptions are flawed. EPA “mines” actual ozone season NO_x emissions data from prior years, but does not properly interpret this information or consider the site-specific nature of boiler operation and coal type as it generalizes data over the entire fleet. Market conditions must be considered for these operating periods, especially for merchant generators. EPA’s approach lacks authentic insight as to design and operating conditions.

This report critiques key EPA assumptions used the technical and cost analyses for electric generating units that supports the propose rule.

Section 3 presents the inventory of electric generating units explored in this evaluation. Section 4 overviews combustion control technology, critiquing EPA’s assumptions addressing NO_x emission control capability and the time required to retrofit new emission controls. Section 5 critiques EPA’s assumption for cost evaluation of postcombustion controls, and proposes inputs that are more realistic. Section 6 presents results of the analysis for this study addressing the incurred cost-per-ton (\$/ton) of control actions. Section 7 summarizes statistical evaluation of 110 high-performing SCR-equipped units, providing insight to the impact of the proposed daily backstop rate.

Section 8 addresses the Generation Shifting element of EPA’s proposal, presenting a detailed data analysis for nine example states demonstrating the flaws in EPA’s analysis, and the challenges of balancing the shifts in generation for affected units. A summary of the errors and challenges due to the EPA’s assessment of NO_x state budgets and compliance for the nine example states is presented in Section 9.

Appendix A presents maps for the nine states evaluated for impact of generation shifting, that identify and show the location of the stations projected by EPA to be most affected. Appendix B summarizes the public information available regarding unit announced retirements.

¹ Technical Support Document (TSD) for the Proposed Federal Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standard, Docket ID No. EPA-HQ-OAR-2021-0668. February 2022. Hereafter EGU TSD.

3. Generating Unit Inventory

3.1 Inventory: This Study

Section 3 describes the inventory of the units in the 25-state region, accounting for differences in unit inventory between this study and EPA. For example, in the evaluation of SCR retrofit, EPA includes the electric generating units in the 25 states applicable to the program, and an additional 38 units in 10 other states. These additional units are not to be representative of the units in the 25 states and distort the incurred cost per ton for the units in the 25 states included in the proposed rule. EPA did not justify inclusion of the additional states in the 25-state evaluation.

Figures 3-1 and 3-2 present basic metrics of the generating units in the 25 states. Figure 3-1 reports the number of coal-fired boilers, coal fluidized bed steam boilers, and oil/gas boilers within the 25 states, showing approximately 340 coal-fired steam generators and 200 oil/gas-fired steam generators. The bar chart also reveals the partitioning of units above and below the 100 MW capacity threshold proposed by EPA to designate oil/gas-fired units that could be required to deploy SCR. The 100 MW threshold potentially exposes 150 oil/gas-fired units to retrofit SCR, depending on if their ozone season NO_x emissions exceeds 150 tons.




Figure 3-1. Inventory of Boilers in the 25 State Region

Figure 3-2 presents the number of units presently equipped with either SCR or SNCR within the 25-state inventory. Regarding coal-fired units, a total of 169 are presently equipped with SCR with an additional 43 featuring SNCR. In reference to units fired by oil and/or natural gas, nine are equipped with SCR while 17 are equipped with SNCR.




Figure 3-2. Inventory of Boilers in the 25 State Region

Figure 3-2 also reports units featuring solely combustion NO_x controls; there are 34 that fire bituminous coal, 71 that fire subbituminous coal, 37 that fire a blend of bituminous and subbituminous, and four that fire lignite. Consequently, in the 25-state region a total of 146 coal-fired units could be considered as candidates to retrofit SCR.

The cost evaluation presented in this analysis is based on the boiler inventory as described above.

3.2 Inventory: Units without SCR

Table 3-1 compares the inventory of units not equipped with SCR that are candidates for retrofit, for both the coal-fired and oil/gas-fired categories, as interpreted by both EPA and the MOG/NRECA/APPA study (This Study).

Table 3-1. Inventory of Units Considered for SCR Retrofit: Coal and Oil/Gas Fired

Fuel	Candidate Units	Candidates That Meet Criteria	Units in non-study states	States Beyond 25
EPA				
Coal	204	126	38	AZ, CO, FL, IA, KS, MT, NC, ND, NE, WA
Oil/Gas	166	78	14	AZ, CT, FL, IA, MA, ME, NM
This Study				
Coal	229	94		
Oil/Gas	142	36		

As Table 3-1 shows, for coal-firing, EPA considered 204 units with 126 meeting the selection criteria in all states.² EPA included in this total of 126 units an additional 38 units in 10 additional states, with 85% of units in the latter firing subbituminous and lignite coal compared to 75% within the 25-state region. The additional 38 units feature lower cost per ton of NOx removed by approximately 11% - imparting significant bias to the 25-state region.

For oil/gas firing, EPA considered 166 units with 78 meeting the selection criteria³ in the 25 states. A total of 14 additional units are introduced into the database from 7 additional states.

This study considered for coal-firing a total of 229 units, of which 94 meet the inclusion criteria (and approximating the 88 units considered by EPA). For oil/gas firing this study considered 142 units as candidates, identifying 36 that met the criteria in the 25 states.

3.3 Inventory: Units with SCR

Table 3-2 compares the inventory of units equipped with SCR for both coal-fired and oil/gas-fired categories, as considered by both EPA and for work reported for this study. As Table 3-2 shows, for coal-firing, 226 units are considered by EPA with 172 meeting the selection criteria in all states. EPA included in this total an additional 46 units in nine additional states.

² Generating units were considered with a “nameplate” rating of 100 MW or greater, and emitted more than 0.14 lbs/MBtu.

³ Electric generating units – per EPA’s proposal - are required to retrofit SCR if the unit “nameplate” generation is rated for 100 MW or greater.

Table 3-2. Inventory of Units Equipped With SCR: Coal and Oil/Gas Fired

Fuel	Candidate Units	Candidates That Meet Criteria	Units in non-study states	States Beyond 25
EPA				
Coal	226	172	46	AZ, FL, GA IA, KS, MT, NC, NH, and SC
Oil/Gas	20	16	5	CA and MA
This Study				
Coal	175	77		
Oil/Gas	11	0		

For oil/gas firing, EPA identified 20 candidate units of which 16 meet the selection criteria in the all states. Five additional units are introduced into the database from two states.

This study considered 175 SCR-equipped coal-fired units, of which 77 meet the inclusion criteria⁴ (approximating the 88 units considered by EPA). The inventory of units in this study is smaller than EPA, as this study considered only the 25 states subject to the proposed rule. Consistent with a correct interpretation of marginal cost, this study examined only units in the 2021 ozone season that emitted NO_x at greater than 0.08 lbs/MBtu - such units already complying with the target value would not require additional actions and incur a marginal cost. This is in contrast to EPA's approach of conducting a "revisionist" calculation of compliance cost, using the from the boiler NO_x outlet rate to define the NO_x removal.

For oil/gas firing, this study considered 11 units as candidates; none were identified to meet the criteria in the 25 states.

⁴ Similar to coal-fired units, a nameplate capacity of 100 MW or greater and 2021 NO_x emission rate of 0.14 lbs/MBtu.

4. Combustion Control Capability

4.1 Introduction

EPA over-estimates the capability of advanced combustion controls to limit boiler NO_x emissions to extremely low rates (per lbs/MBtu). EPA appears to define advanced combustion controls as some combination of low NO_x burners and overfire air, both of which delay or “stage” the combustion process to create NO_x-reducing regimes with a flame. EPA does not offer any other definition of advanced technology, but appears to treat a unit that emits NO_x at greater than 0.25 lbs/MBtu as not equipped with advanced technology.⁵

Specifically, EPA notes in the EGU TSD:⁶

Modern combustion control technologies routinely achieve rates of 0.20 – 0.25 lb NO_x/MMBtu and, for some units, depending on unit type and fuel combusted, can achieve rates below 0.16 lb NO_x/MMBtu.

The NO_x emission rates cited by EPA as attainable are based on fuel composition that cannot be extrapolated to the national inventory. EPA does not recognize – especially for tangential-fired boilers firing bituminous coal – these reference fuels are atypical. Consequently, EPA does not acknowledge the error inherent in generalizing NO_x emission rates from a small subset of boilers to the national inventory. Further, EPA did not conduct a detailed cost evaluation of combustion controls; rather EPA used costs derived from a 2011 study that is part of IPM documentation⁷ for which reference data is not shared. Rather, EPA cites calculations using a static spreadsheet-based evaluation that determines total (not incremental) costs for an “illustrative unit”⁸ to be less than \$1,600/ton.

4.2 Referenced Units

EPA identified 53 tangential-fired units and 39 wall-fired units equipped with advanced combustion controls. Figures 4-1 depicts for the EPA reference tangential-fired boilers the 2021 ozone season average of NO_x emissions as reported to EPA. Figure 4-2 depicts the 2021 ozone season NO_x average for the EPA reference wall-fired boilers. EPA proposes these units typify candidate units in the national fleet. This assumption is in err.

⁵ EGU NO_x Mitigation TSD, page 14.

⁶ Ibid.

⁷ https://www.epa.gov/sites/default/files/2015/07/documents/chapter_5_emission_control_technologies_0.pdf. Table 5-4.

⁸ Ibid, page 16 and footnote #23, 24.




Figure 4-1. 2021 Average Ozone Season NOx Emissions: Tangential-Fired Boilers Firing Bituminous, Subbituminous, Blends and Lignite Coals




Figure 4-2. 2021 Average Ozone Season NOx Emissions: Wall-Fired Boilers Firing Bituminous, Subbituminous, Blends and Lignite Coals

Success with combustion controls requires several boiler characteristics: generous surface area adjacent to the burners for heat removal, generous burner spacing, and adequate distance to “stage” the combustion process with overfire air ports. That the EPA candidate boilers are retrofit with such controls – in lieu of others units in the fleet - suggests these units offer the physical features for successful combustion staging, and control of NO_x. The reference units in Figures 4-1 and 4-2 may not represent other boilers in the national fleet. Extrapolating combustion control capability as described by EPA requires a thorough analysis to define these characteristics for the domestic boiler fleet.

4.2.1 Tangential-Fired Boilers

Figure 4-1 reports NO_x data for 11 tangential-fired units designated by EPA as firing bituminous coal, with the results suggesting approximately 0.20 lbs/MBtu as achievable. This depiction is inaccurate, as the fuels as reported by EPA as bituminous are misleading. Based on EIA Form 860 data for 2020, the RM Schaffer units fire a bituminous/subbituminous blend. The Navajo and Hunter units fired western bituminous – the composition of which lacks the sulfur content and acid/base ratio of eastern bituminous coals that are problematic in achieving the deep staged conditions required for low NO_x. Also, differences in coal nitrogen content and the inherent volatility assert an impact. The Hunter units fire a refined variant of bituminous coal – an option not available in 2022. Only IPL-Petersburg Units 1 and 4 fire an authentic bituminous coal of composition that could be considered representative of U.S. fuels. Further, EPRI estimates the median value of NO_x emissions from tangential-fired boilers firing bituminous coal to be 0.35 lbs/MBtu for LNCFS-II and 0.34 lbs/MBtu for LNCFS-III, with values for the latter option as high as 0.47 lbs/MBtu.⁹ This information – albeit derived from a 2003 summary – reflects the present status of technology cited by EPA, as the NO_x emission rates less than 0.10 lbs/MBtu were publicly cited in 2000.¹⁰

Data is also shown for five units firing a bituminous/subbituminous blend, two lignite-fired units, and 32 subbituminous-fired units. Almost all subbituminous coals are from the Power River Basin (PRB), which due to high fuel volatility and excess alkalinity enable “deep” staging conditions that support low NO_x. PRB moisture content can be four times the moisture content of bituminous, with half the nitrogen content – both important factors. The extremely low NO_x emissions (< 0.10 lbs/MBtu) observed on units at the Rush Island and Labadie stations are achieved with favorable volatility by even PRB standards. It is unreasonable to assume that PRB coal or PRB-like coal with these properties can be broadly acquired, thus their role establishing an average NO_x rate should be discounted.

4.2.2 Wall-Fired Boilers

Figure 4-2 reports NO_x data for eight wall-fired boilers EPA cites as firing bituminous coal, with the results suggesting NO_x emission less than 0.20 lbs/MBtu as achievable. As noted

⁹ EPRI 2002 Workshop on Combustion-Based NO_x Controls for Coal-Fired Boilers, EPRI Report 1007579, January 2003. Hereafter EPRI 2002 Workshop. See page 2-96.

¹⁰ Neural Networks Prove Effective at NO_x Reduction, NS Energy, May, 2000. Available at <https://www.nsenergybusiness.com/features/featureneural-networks-prove-effective-at-nox-reduction/>

previously, these units likely offer physical features that enable high performance of combustion controls – generous surface area per unit volume for heat release, burner spacing, and adequate distance to allow separation of overfire air and elongated flame length.

Regarding the eight bituminous fired units, the two lowest NO_x emitting units are not further considered due to aberrant control technology or fuel type. Specifically, Chalk Point employs SNCR as a supplementary control step and Hunter fires 100% refined coal. Refined coal is not an option available in 2022 and beyond and is not considered representative. The remaining units are too small in generating capacity to register significance for the national fleet. Three units are extremely small, limiting their ability to confidently scale results to larger capacities - two R. Gallagher units are each 140 MW and Whitewater Valley is 35 MW. The three Alcoa units – each at 166 MW – are also of generating capacity not representative of the national fleet of wall-fired boilers. EPRI estimates the median value of NO_x emissions from wall-fired boilers firing bituminous coal and employing LNB with OFA to be 0.36 (for opposed wall firing) to 0.40 lbs/MBtu (for single wall-firing), with values as high as 0.46 lbs/MBtu observed.¹¹

Five units are referenced firing a blend of bituminous/subbituminous. The lowest NO_x-emitting unit (Erickson) does not fire a blend of coal but rather 100% subbituminous; the next lowest NO_x emitting unit (RD Nixon) fires a blend of subbituminous and natural gas. The two Martin Drake units are 75 and 132 MW, respectively.

As acknowledged previously, subbituminous coal enables low NO_x firing conditions, particularly for coals with high volatility. The lowest emitting units are small – Neal Simpson II (90 MW) and are not representative.

Takeaway. For both tangential and wall-fired boiler, EPA’s projected NO_x emission rates are based on atypical fuels and unit design and are not representative of the national fleet. Many owners have already retrofit combustion controls with advanced mixing and some degree of overfire air, and thus already are equipped with the essentials of advanced control technology. One owner (LG&E/KU) through 2014 has retrofit eleven generating units with some form of advanced control technology, eliciting supplier guarantees ranging from 0.21-0.37 lbs/MBtu.¹²

The most significant error in EPA’s methodology concerns bituminous coal, in which western bituminous or refined coals are wrongly cast as representing conventional bituminous. In addition, extrapolating results from units less than 200 MW to the national inventory is not straightforward and requires considering factors such as furnace surface area, combustion product flow volume, and distance available over which to mix fuel and air. The extrapolation of subbituminous-fired results must also be executed with caution, as even PRB volatility – which affects NO_x control performance –can widely vary.

¹¹ Ibid. See page 2-93.

¹² Personal Communication, LG&E and KU Energy LLC Staff: June 15, 2022.

4.3 Generalizing Results to Boiler Population

The results highlighted by EPA are not readily generalized over the 25 states due to variations in fuel composition, fuel characteristics, and boiler type. EPA's assumptions are flawed in terms of the ability to reach the low levels of NO_x cited in the previous figures.

4.3.1 Fuel Composition

EPA does not consider the role of coal composition and characteristics, or the design “vintage” of the boiler on the performance of combustion controls and resulting NO_x emissions. Each of these factors is addressed below:

The composition and characteristics of fuel drive NO_x control capability with coal – most notably from PRB. The key coal features are nitrogen content and reactivity – the latter reflected in the *Volatile Matter* and *Fixed Carbon* characteristics of the fuel. PRB coal features high reactivity which enables nitrogen within the fuel to rapidly evolve from solid to gas phase and experience oxygen-deficient conditions which prompt the reaction paths to molecular nitrogen.¹³

NO_x control capability is greatest when liberated fuel-bound nitrogen is exposed to oxygen-deficient conditions for the longest residence time. PRB coal presents a second advantage in maximizing oxygen-deficient conditions while avoiding boiler watertube corrosion. In contrast, these same low NO_x conditions when created for bituminous coals generate sulfur-containing, corrosion-inducing species. Selecting proper materials for boiler walls can limit corrosion damage, but it is still advised that “minimizing substoichiometry” (e.g. creating oxygen-deficient conditions) limits damage to boiler tube walls.¹⁴ In concept, limiting coal sulfur and chlorine content can safely achieve lower NO_x rates, but this practice restricts the use of high sulfur coal.

The implications of these observations are clear – PRB coal with extremely low sulfur and nitrogen content, combined with high inorganic alkaline content, minimizes the production of corrosive species thus enabling PRB-fired burners to exploit low NO_x conditions, but such options are not available to the general population of units in the 25-state region and are not representative of the fleet as a whole. Therefore, EPA's failure to distinguish characteristics of coal used in its analyses results in a generalization that distorts its conclusions.

4.3.2 Boiler Design

Equally important to the role of fuel composition is boiler design - perhaps most important is the heat release intensity and furnace geometry. These two features are related; a generous furnace sizing allows typically elongated low NO_x flames to not impede heat transfer or prompt flame

¹³ *Retrofit NO_x Controls for Coal-Fired Utility Boilers: A Technical Assessment Guide for Meeting the Requirements of the 1990 Clean Air Act Amendments*, EPRI Report TR-102071, 1994. See Box 7-1. Also see Paschedag, A., *Combustion and NO_x 101*, Advanced Burner Technologies for the 2008 WPCA Roundtable, February 2008, Richmond, VA.

¹⁴ Kalmanovitch, D., *Waterwall Corrosion Due to Low NO_x Combustion – Material Choices*, presented to the 2007 NO_x Round Table and Expo, February 2007, Cincinnati, OH

impingement. Also, generous furnace sizing presents lower heat release intensity, a design feature quantified as the Burner Zone Liberation Rate (BZLR) which each boiler designer interprets and defines differently.

Figure 4-3 presents a general boiler layout used to define the BZLR for the four major boiler suppliers.¹⁵ Prior to concerns for NO_x reduction, BZLR was selected to maximize fuel utilization (e.g. achieve minimal carbon burnout) and avoid furnace corrosion while minimizing boiler footprint – a key factor that determines capital cost. NO_x control mandates changed boiler design criteria – BZLR was specified to support controlling NO_x emissions.¹⁶ This change in BZLR was prompted by the need to lower flame temperature to minimize thermal NO_x and provide space for low NO_x burners and the associated extended-length flames. The most recent boiler designs employ relatively low BZLR to achieve these NO_x rates.




Figure 4-3. Definition of Burner Zone Liberation Rate: Four Major Boiler Suppliers

In summary, BZLR is key in minimizing NO_x emissions. The retrofit of advanced combustion controls may not provide the same NO_x control on earlier “legacy” boilers with higher BZLR compared to more recent designs with lower BZLR values. Figure 4-4 depicts the evolution of advanced boiler technology by one supplier (B&W), showing the progress achieved in recent

¹⁵ Retrofit of NO_x Controls for Coal-fired Utility Boilers, EPRI Report for Research Project 2916-7 December 1993. See Figure 3-8.

¹⁶ J. Vatsky, Development and Field Operation of the Controlled Flow Split Flame Burner, Proceedings of the 1981 Joint EPA/EPRI NO_x Control Symposium, Denver, CO, 1981.

decades with both subbituminous and bituminous coals. None of these systems achieves the lowest NO_x rates, reported by EPA in Figures 4-1 and 4-2 as less than 0.10 lbs/MBtu.




Figure 4-4. Wall-Fired Boiler Experience with Evolving Low NO_x Burner Technology

4.3.1 Owner Experience

The challenge of meeting NO_x emission rates as proposed by EPA with bituminous coal was experienced by a Midwest Ozone Group (MOG) member utility. This owner evaluated a tangential-fired boiler firing bituminous coal for an upgrade from LNCFS II to LNCFS III technology.¹⁷ Unit NO_x emissions could not approach 0.25 lb/MBtu with a coal prone to slagging (e.g. high Fe content) and corrosion due to high sulfur and chlorine content. A negligible benefit in NO_x reduction was derived evolving from LNCFS II to LNCFS III. The owner was advised by a third-party consultant that reduction in boiler exit NO_x beyond approximately 0.35 lbs/MBtu would affect the reliability of the unit due to slagging and corrosion on the waterwalls. This experience is consistent with the earliest reports of LNCFS II and LNCFS III control technology on bituminous coal, which report LNCFS II reduces NO_x by 40-50% of uncontrolled values, while LNCFS III is capable of up to 50% NO_x reduction.¹⁸

¹⁷ The supplier of tangential-fired boiler technology commercial terminology for advanced combustion controls is the Low NO_x Concentric Firing System, or LNCFS. There are three variant or “levels” of this technology, defined as LNCFS-1, LNCFS-2, and LNCFS-3.

¹⁸ *Alternative Control Techniques Document – NO_x Emissions from Utility Boilers*, Report EPA-453/R-94—023, March 1994. See page 5-54.

The owner opted to retain the existing LNCFS II burners and employ a neural network control system to lower NO_x and minimize the slagging and corrosion issues.

4.4 Revised Control Capability, Cost

Revised NO_x control performance and cost are presented in this subsection.

Advanced combustion controls are capable of reducing NO_x by replacing ‘legacy’ burners in existing units – but not to the extent envisioned by EPA. The data presented in Figures 4-1 and 4-2 represents favorable fuel and furnace arrangement – and do not reflect the domestic fleet. The NO_x emission rates cited in the EPRI survey represent a second rationale source.

The NO_x emission rates in Table 4-1 represent values from the domestic fleet that account for the variability in fuel composition and firing equipment. These values represent averages of the high and low values, and thus consider data in Figures 4-1 and 4-2 while accounting for units that due to fuel and equipment limitations achieve the higher NO_x emission rates.

Table 4-1. Average Achievable NO_x Emissions Rates

Coal Rank	Tangential-Fired	Wall-fired
Bit	0.30	0.32
Lignite	0.20	0.22
PRB	0.15	0.19

Regarding the cost of combustion controls, the EGU TSD notes:¹⁹

Consequently, EPA identifies \$1,600/ton as the cost level where upgrades of combustion controls would be widely available and cost-effective.

A simple analysis shows these costs to much higher. Using the capital, fixed O&M, and variable O&M from Table 5.4 of the IPM 5.13 documentation,²⁰ the total cost of deploying advanced low NO_x firing equipment to a tangential-fired and wall-fired 300 MW boiler operating at 10,000 Btu/kW and a 56% capacity factor is \$3,345,200 and 2,055,529 dollars (2021 basis). For the wall-fired boiler, lowering NO_x for bituminous firing from 0.40 to 0.30 lbs/MBtu incurs a cost of \$4,506/ton, while for PRB using these means to lower NO_x from 0.30 to 0.19 lbs/MBtu incurs a cost of \$4,132/ton. For the Tangential -fired boiler, lowering NO_x for bituminous firing from 0.35 to 0.25 lbs/MBtu incurs a cost of \$2,793/ton, while for PRB using these means to lower NO_x from 0.22 to 0.15 lbs/MBtu incurs a cost of \$3,990/ton. The \$1,600/ton referenced by EPA for widely available controls and cost effectiveness is biased due to unrealistic input assumptions, and bears no resemblance to our analysis.

¹⁹ EGU TSD, see page 10.

²⁰ https://www.epa.gov/sites/production/files/2015-07/documents/chapter_5_emission_control_technologies_0.pdf

4.5 Installation Schedule

EPA's actions are premised on owners being able to complete installation of new combustion hardware within a time frame that allows compliance with the 2024 ozone season NO_x rates - basically, less than 12 months from this report date. EPA's basis for this assumption is not strong — EPA cites an 11-year old document²¹ purported to reflect the hardware requirements of state-of-art-combustion controls. However, this document cites only two installations, each of which reported retrofit in 6 months.

Table 4-2 reports retrofit experience of significantly more than two units – six owners, eight stations and eleven boilers. Table 4-2 presents significant detail, reporting not just total time from project conception and preparation through startup, but the specifics of time required for major steps. The present issues of labor shortages and supply chain disruption are not reflected in Table 4-2, and will further extend project schedules. Table 4-2 shows that on average 22 months is required to complete the entire project scope – suggesting at best that if project conception started immediately, a large fraction of these units could be ready for the 2025 ozone season.

EPA proposes “Step 2” of the compliance process for all units equipped with postcombustion controls to first ‘optimize’ the compliance process by adopting advanced combustion controls. The time required for such actions presents Step 2 from being practically achieved, and is not considered feasible (and this not further addressed in this report).

Takeaway: EPA's projection of low NO_x emission rates is flawed, particularly for bituminous coal, as only three units are valid references while others represent atypical cases of western bituminous, refined coal, or are co-fired when reported as exclusive bituminous. Only newer generating units that feature relatively low Burner Zone Liberation Rates could replicate the claimed low NO_x conditions; many boilers designed for NO_x New Source Performance Standards (NSPS) prior to 1997 or for a narrow range of coal properties will be challenged unlikely to achieve these rates. In summary, EPA's projection of the NO_x control capability of advanced combustion controls is flawed as it does not fully consider coal rank, boiler design features, and operating characteristics. As a result, the incurred cost per ton of NO_x removal is higher, due to lower mass of NO_x removed.

The time required for installation – an average of 22 months based on a survey of 11 boilers - significantly exceeds the time available to enable retrofit for the 2023 ozone season. Notably, the 22-month is an average – one public power entity incurred between 48-60 months for the entire scope of activities, including arranging financing (required prior to any significant actions) and regulatory approval prior to installation to achieve cost recovery. Merchant generators will not require such approval, but are required to justify the need with certainty to a lender.

²¹ Installation timing for Low NO_x burners (LNB), Technical support Document for the Transport Rule, docket ID No. EPA-HQ—OAR-2009-0491.

Table 4-2. Combustion Control System Acquisition, Installation Time

Owner	Units	Equipment Scope	Project Duration (Months)	Required Outage (Days)	Details of Timeline (Months)
Ameren	Rush Island 1, 2	LNCFS Level 3 (from LNCFS Level 1)	31/35	75	Engineering: 10 Fabrication: 5 Installation: 6
APS	Cholla 1	LNCFS Level 2 (from LNCFS Level 1)	22	46	N/A
	Cholla 2/3/4	Same as above	26/28/35	39/57/54	N/A
Duke	Roxboro	LNB, digital control system	18	60	Prep: 2; Bid 2 Fabricate: 12; Install 2
	Lee 1, 2	Separated OFA	18	60	N/A
SRP	Coronado 1, 2	LNB/OFA	21/20	49/42	Prelim:6; Proposal: 3 Final design:3; Fabrication:7 Installation: 2
We Energies	Oak Creek	LNCFS 3 (From LNCFS Level 2)	24		22 months once contract final
	Valley	LNB	20		22 months once contract final
Midwestern		LNB, OFA (TFS 2000)	15-18	90-100	N/A

5. POSTCOMBUSTION NO_x CONTROL

Section 5 presents comments on EPA evaluation of the feasibility and cost effectiveness of both SCR and SNCR NO_x control.

5.1 Selective Catalytic Reduction (SCR)

The EPA proposes requiring additional NO_x reduction from units presently equipped with SCR, and retrofitting SCR to units equipped to date with combustion controls or SNCR. This section reviews the technical and cost premises EPA adopts to support their actions.

5.1.1 Performance Basis

EPA's assumes owners of existing SCR-equipped units are not "fully operating" this process equipment to the maximum capabilities, extracting only that NO_x required to meet the present standard or allowance position.²² While possibly true in some cases, EPA's estimate of additional capabilities for the costs is flawed.

EPA submits any unit's maximum NO_x removal potential is demonstrated by the "third-lowest" ozone season emission rate observed since 2012. In practice, this methodology reflects only a snapshot in time of a unit's performance. It is well-known NO_x control performance degrades with the state of the catalyst, and ability to maintain a uniform mixture of ammonia reagent with NO_x generated in the boiler. A "third-lowest" NO_x emission rate could reflect the immediate benefit of the exchange of catalyst and the increase in catalyst activity; EPA's analysis does not account for this possibility. Both the physical state of the catalyst and the ability to achieve a high degree of ammonia-to-NO_x uniformity will degrade with time, and change year-to-year. EPA is in error to assume such NO_x rates can be indefinitely attained from existing equipment – or, attained but with additional capital expenditure to refresh the catalyst inventory, or incur higher variable operating and maintenance (O&M) cost that projected by EPA. This analysis will assess NO_x emission rates that are broadly achievable with SCR, requiring for some units either enhanced O&M practices and (in limited cases) capital improvement.

A further premise of EPA's propose rule is that present-day state-of-art SCR reactors retrofit to existing units can achieve ozone season NO_x rates of 0.05 lbs/MBtu. A review of NO_x emissions data from SCR-equipped units examined in this study shows 17 units averaged NO_x emissions of less than 0.05 lbs/MBtu in the 2021 ozone season. A statistical evaluation of these NO_x outlet rates shows for almost half of operating time (47%) NO_x emissions range between 0.04—0.05 lbs/MBtu, with the remaining time distributed at rates both below and exceeding the 0.05 lbs/MBtu target value. As to be discussed, the cost per ton of NO_x removed for such deep NO_x removal can be exorbitant, if boiler exit emissions are less than 0.15 lbs/MBtu.

²² EGU-TSD. Page 2.

5.1.2 Cost Basis

The cost basis for SCR is addressed both for retrofits and to units presently so-equipped.

New SCR Retrofit. EPA's evaluation of the feasibility for "widespread" implementation of SCR employs a cost estimating procedure issued by Sargent & Lundy that reflects both capital and operating cost.²³ The capital cost-estimating procedure – although an improvement over past methodologies applied by EPA in rulemaking – does not adequately capture retrofitting SCR into the remaining units in the coal-fired fleet. S&L note that cost components are derived from surveys and analysis conducted by *the authors of this document* over the time from as early as 2004 and through 2013, with these data "significantly augmented" by S&L in-house data.²⁴ The transparency in the source data is appreciated. However, *the authors of this document* submit that such costs are outdated and most relevant to early SCR installations, whereas candidate units in the remaining inventory differ in layout and baseline NOx emissions.

The analysis presented in this document will employ an adjusted version of the capital cost relationship proposed by S&L and utilized by EPA, as depicted in Figure 5-1 for the three coal ranks and including a relationship for oil/natural gas firing. This SCR capital cost relationship is derived from the "Retrofit-Cost-Analyzer-Update-1-26-2022".

Figure 5-1 shows the cost correlation well-reflects four estimates recently prepared for project participants. That a factor-of-two variation observed between several of the estimates (Flint Creek, Craig Unit 3) is not unusual –industry experience shows such variations are not uncommon, due to varying site conditions. (Such variations are the rationale for the "Retrofit Factor", subsequently described).

Figure 5-1 presents SCR capital costs for units firing these three ranks of coal. The SCR process conditions and the percent NOx removal required are inputs to the Retrofit-Cost-Analyzer-Update-1-26-2022 to generate capital cost. For bituminous units, a boiler NOx rate of 0.32 lbs/MBtu is assumed, targeting 85% reduction. For both PRB and lignite fuel ranks, a boiler NOx rate of 0.22 lbs/MBtu is assumed, targeting 80% NOx reduction

Also included in Figure 5-1 is a cost of \$25/kW assumed necessary for pre-2005 SCR reactors to refurbish existing catalyst, retrofit enhanced catalyst cleaning devices (to remove accumulated fly ash deposits), and where necessary retrofit improved reagent mixing and flue gas rectification hardware (to improve flow velocity entering the SCR reactor). These or similar modifications will be necessary for pre-2005 SCR reactors to accommodate the changes proposed by EPA.

²³ IPM Model – Updates to cost and Performance for APC Technologies, SCR Cost Development Methodology for Coal-fired boilers, Final Report for Project 13527-002, February 2022.

²⁴ Ibid. See page 1. The 2004 to 2006 industry cost estimates for SCR units from the "Analysis of MOG and LADCO's FGD and SCR Capacity and Cost Assumptions in the Evaluation of Proposed EGU 1 and EGU 2 Emission Controls" prepared for Midwest Ozone Group (MOG) were used by Sargent & Lundy LLC (S&L) to develop the SCR cost model. In addition, S&L included data from "Current Capital Cost and Cost-effectiveness of Power Plant Emissions Control Technologies" prepared by J. E. Cichanowicz for the Utility Air Regulatory Group (UARG) in 2010 and 2013.




Figure 5-1. Capital Cost vs Capacity Relationship for SCR NOx Control: Coal and Distillate Oil/Natural Gas

Two inputs to the cost correlation – and an adjustment to the escalation methodology – are reflected in the data in Figure 5-1. First, it will be assumed that half of projects will deploy “EPC” (engineer, procure, construct) contracts. S&L assigns a 15% premium cost for such contracting arrangement; consequently a 7.5% premium is elected to account for this action over the unit inventory. A second input is the selection of the Retrofit Factor – which without a specific site to evaluate, is assigned a value of “1”.

Third, capital costs are adjusted to reflect recent escalation not captured by EPA. Specifically, S&L escalates costs used in the Retrofit-Cost-Analyzer-Update-1-26-2022” from 2011 to 2021 at an annual rate of 2.5% which does not capture recent trends. For this analysis, the S&L methodology is accepted through 2019 and the Chemical Engineering Process Equipment Index (CEPCI) used to escalate costs from 2019 to a mid-2021 basis. Adopting this latter approach transforms 2011 costs into a mid-2021 basis with a factor of 1.41, compared to 1.28 as utilized by EPA.

For new retrofits, the target NOx emission rate of 0.05 lbs/MBtu represents a significant reduction from the 0.08 lb/MBtu assigned to existing SCR-equipped units. In a separate study for a power station in the Southeast, S&L advised that a design compliance margin of 0.02-0.03

lbs/MBtu be adopted.²⁵ Further, statistical evaluation of the 17 units described in Section 5.1.1 as meeting the target value of 0.05 lbs/MBtu operate for a significant number of hours at a 0.04 lbs/MBtu average. Consequently, for this analysis the target NOx rate to determine operating costs to achieve an average of 0.05 lbs/MBtu is assumed to be 0.04 lbs/MBtu.

Selecting a NOx operating rate below the 0.05 lbs/MBtu proposed limit – if even feasible – is also justified by the structure of the proposed rule. The target emission rate must provide adequate margin to generate “excess” allowances that can be traded or utilized on units for which SCR retrofit is not feasible.

Figure 5-1 also presents SCR capital cost for units firing oil and natural gas as derived with the *S&L Retrofit-Cost-Analyzer-Update-1-26-2022* file. Analogous to coal-fired evaluation, a cost premium of 7.5% is assigned to address the prospects for half of the inventory employing an EPC contract. A Retrofit Factor of 1 is used. Costs were escalated from 2011 to 2019 the same approach as described for coal-firing.

SCR-Equipped Units. Coal-fired generating units presently equipped with SCR will be assumed to employ enhanced O&M to achieve the ozone season average of 0.08 lbs/MBtu. To achieve an average rate of 0.08 lbs/MBtu over the ozone season an operating rate of 0.075 lbs/MBtu is selected, to provide margin for startup, shutdown, and equipment reliability.

Enhanced O&M practices entailing accelerated catalyst replacement, aggressive catalyst cleaning, and annual tuning reagent injection equipment will be required to achieve the 0.075 lbs/MBtu target rate. Further, early-generation reactors – those in service preceding 2005 - will be assigned a modest capital charge (~\$20-25/kW) to update select hardware. The rationale for capital investment is based on the observation that many first-generation reactors (a) are not equipped with state-of-art means to remove accumulated fly ash deposits, or reagent injection hardware, (b) do not optimally distribute incoming flue gas into the SCR reactor, or (c) employ cavities for three (and not four) layers of catalyst, limiting catalyst management actions. Most widespread is the chronic inability to maintain clean catalyst surface, maximizing NOx reduction. Figure 5-2 presents an image of a catalyst layer plagued by ash deposition, as summarized in an owner’s catalyst assessment report. Consistently achieving less than 0.08 lbs/MBtu will require equipment upgrades to avoid the catalyst state as depicted. An estimate of the capital required (\$/kW basis) is presented in Figure 5-1 as a function of generating capacity.

²⁵ NOx Control Technology Cost and Performance Study, Entergy Services, Inc. – White Bluff and Lake Catherine. Report SL-011439, Prepared by Sargent & Lundy, May 16, 2013. Note: contained within Response to January 8, 2020 Regional Haze Four-Factor Analysis Information Collection Request, prepared by Trinity Consultants for Entergy, April 7, 2020.




Figure 5-2. Ash Deposition on Catalyst Impeding NO_x Removal Performance

Operating costs are derived from the *S&L Retrofit-Cost-Analyzer-Update-1-26-2022* file. As identified by EPA, not all fixed and variable O&M costs will be assigned to the marginal cost of increasing NO_x reduction beyond that incurred in 2021. Fixed O&M and the variable cost for power are invariant with NO_x reduction. Reagent use and catalyst replacement do increase with NO_x reduction. As with the case for new retrofit installation, the variable O&M for catalyst will be increased by approximately 9% for applications requiring more than 80% NO_x reduction.

5.2 Selective Non-Catalytic Reduction (SNCR)

The EPA proposes SNCR be applied to coal-fired units less than 100 MW in generating capacity, and to oil/gas units greater than 100 MW of capacity that emit more than 150 tons of NO_x annually.

5.2.1 Performance Basis

EPA states SNCR control capability ranges from 20-40%, depending on the application. Similar to SCR, extracting lower NO_x emissions is achieved in exchange for introducing residual NH₃ into the gas stream. Unlike SCR, the level of residual ammonia is typically higher than observed with SCR. As noted previously, reagent injected that does not experience the optimal temperature window will oxidize to NO_x.

The ability of SNCR to remove NO_x generally decreases with lower boiler NO_x content, and limits on physical conditions that limit the space between various rows of injection lances.

Further, boiler generating capacity also determines the distance over which urea must be injected and retained in form to release NH₃ increases – as does the opportunity to revert to emissions of NH₃ or be oxidized to NO_x. Consequently, the highest NO_x removal allowed for units with (a) boiler NO_x emission rates of 0.15 lbs/MBtu or less, and (b) boiler of 200 MW and higher is limited to 30%.²⁶

The key technical challenge for SNCR is achieving rapid mixing of urea reagent into a relatively narrow temperature “window”, that supports effective reduction of NO_x. For most applications, this temperature window ranges from 1,800 – 2,200 F.²⁷ Unlike SCR, reagent injected for SNCR outside this optimal temperature window generates not only residual NH₃ but is oxidized to NO_x – completely counterproductive to the step of NO_x control. A key complication is that the physical location of the optimal temperature window – usually near the furnace exit - is not “static” but changes with changes in load. Both enhanced capital investment and a design methodology using computational fluid dynamics (CFD) can increase the opportunity to inject urea into the optimal temperature window. Capital investment enables employing an array of multi-layer injectors to tailor the injection of reagent to follow the temperature window. A thorough design basis employing CFD –requiring exacting details of boiler design – can identify the location of the temperature window and predict movement with load. Both the investment required and time for design and installation are affected.

The effectiveness of SNCR is compromised significantly with low NO_x concentration. Specifically, EPRI reports²⁸ that results from numerous SNCR demonstrations that NO_x control capability is limited for NO_x concentrations approximating 100 ppm (@ 3% O₂) or less (equivalent to approximately 0.15 lbs/MBtu).

5.2.2 Cost Basis

Figure 5-3 presents capital cost for SNCR for coal-fired and oil/gas application, as derived from the S&L reports. Similar to SCR, 50% of the projects are expected to employ an EPC contract, this a premium of 7.5% of capital is assigned. The Retrofit Factor is assumed to be 1. Capital cost is escalated to a 2021-year basis using the CEPCI for the 2019 and 2020, as applied for coal-fired applications.

Ideally, the capital relationships would reflect units where multi-layer injection lances are required to assure reagent injection within the correct temperature window. Ample time for engineering analysis to include detailed CFD evaluation would be accommodated in both schedule and engineering costs. Given the role of SNCR on outcome of the 25-state region, the EPA assumptions as stated in IPM background documentation is adopted, solely for the purpose for the present calculations.

²⁶ Low Baseline NO_x Selective Non-Catalytic Reduction Demonstration, Joppa Unit 3, EPRI Project 1018665, Final Report March 2009. See page 1-1.

²⁷ Ibid.

²⁸ Ibid.




Figure 5-3. Capital Cost vs Capacity Relationship for SNCR NOx Control: Coal and Distillate Oil/Natural Gas

SNCR cost is driven by the delivered price and utilization of reagent for NOx control. In contrast to SCR, where generous time and space for reagent mixing enable almost complete utilization (with minimum loss to molecular N₂ or residual NH₃), for SNCR reagent utilization typically less than 80%.

Operating costs are mostly driven by reagent utilization. These values will vary widely with boiler size, specifics of the furnace outlet and entry to the convective section. Given the role of SNCR on outcome of the 25-state region, the EPA assumptions as stated in IPM background documentation is adopted, solely for the purpose for the present calculations.

5.3 Installation Schedule

Figure 5-4 presents installation schedule information for 18 SCR installations, as managed by ten owners. These data capture all project aspects from planning, conceptual engineering, RFP development, proposal solicitation and review, contract award and negotiation, hardware fabrication and installation. Figure 5-3 shows the typical time required for a single SCR reactor is 40 months, while retrofit of multiple reactors to one site requires 45 months. These authentic, recorded schedules suggest that retrofit of the inventory of approximately 100 units with SCR technology is not feasible.




Figure 5-4. Timeline for Engineering, Procurement, and Installation of SCR Postcombustion Control Technology

Even if the installation timeline could be accelerated, there are simply inadequate resources to deploy SCR to the extent required to meet the proposed rule. Figure 5-5 shows the projected increase in SCR inventory compared to historical work, showing that if all installations entered serve in 2026, the magnitude of installations would exceed that of 2003. The inventory could be staged over several years – as Figure 5-5 shows the SCR inventory required for 2005 was installed over 4 years.

Public power and rural electric co-operative utilities face additional challenges with an abbreviated installation timeline, due to the additional step of approval for and raising capital. Three years to install an SCR for municipal utilities is not adequate. EPA should allow for an extension of compliance deadlines, similar to that afforded for non-EGUs.²⁹ Further, EPA's assumption that owners typically plan a 5-week outage every year – adequate to retrofit SCR – is erroneous. To the contrary, some municipal utilities plan outages of such durations at multiple years.

Finally, a further complication is that owners – to abide by their respective fiduciary responsibilities - cannot initiate major engineering or actions that require significant capital expenditure without a final rule.

²⁹ See 85 Fr 20104.




Figure 5-5. Capacity (MW Basis) of SCR Retrofits Since 1994

The requirement to retrofit numerous SCR installations within a short time period will exacerbate the present imbalance in laborer or contractor shortage, causing delays in SCR installation schedules. Specifically, on rural co-operative owner received a construction estimate showing a 75-month timeline for SCR installation. This estimate significantly exceeds the average noted of 44 months – and means to accommodate these longer timelines should be offered.

6. Cost Evaluation Results: NO_x Control Cost per Ton for Ozone Mitigation

Section 6 presents results of the evaluation of incurred cost per ton for NO_x removal for several categories of units and operating scenarios. These results are based on the input cost data and assumptions described in Sections 4 and 5.

NO_x removal cost is described for coal-fired units (a) with existing SCR, reporting the incremental cost to remove NO_x from the 2021 emission rate, (b) equipped at present with exclusively combustion controls, reporting removal cost via retrofit SCR from the boiler NO_x exit rates, and (c) less than 100 MW, applying SNCR (for 25% removal). Also reported is the removal cost via SCR retrofit to units firing distillate oil/natural gas units, greater than 100 MW, and that emitted more than 150 tons of NO_x per year. The cost per ton is determined for remaining plant lifetime of 10 and 5 years, and for capacity factor (a) adopted by EPA as the reference for this analysis (56% and 26% for coal- and distillate oil/gas-fired, respectively), and (b) at each units' 2021 capacity factor.

6.1 Units without SCR: Retrofit

6.1.1 Coal-Fired Duty

Figures 6-1 summarizes results derived in this study for the 143 units in the 25 states to which SCR is proposed to be retrofit, based on a EPA's assumed capital recovery factor of 0.143 and attendant presumption of a 10-year lifetime.³⁰ Also shown on Figure 6-1 is the cost per ton reported by EPA for their findings on the 35 states, using their assumed input conditions. The latter EPA-derived data is shown for units in the boiler population at the 50% (median) and 90% values. Figure 6-2 presents analogous results calculated for a 5-year remaining lifetime.

Figure 6-1 shows the median cost incurred for a unit to retrofit SCR where none had previously existed to be \$20,250 per ton for operation at 56% capacity factor, while 90% of units in the population will incur a cost not more than \$28,103 per ton. The analysis was also conducted for each generating unit using their unique 2021 capacity factor, with results showing the median cost for the population to be \$24,340 per ton, while 90% of units in the population will incur a cost not more than \$50,000 per ton.

³⁰ EPA does not define a remaining unit lifetime, but rather states the capital recovery factor used for calculations with both the IPM and Retrofit Cost Evaluation Analyzer. The reported capital recovery factor is 0.143, which comports to the recovery of principle and simple interest using a 10-year remaining lifetime and EPA's historical 7% interest rate. This relationship accounts for return of capital only, excludes associated costs for property taxes and insurance, and assumes instant or "overnight" construction. The relationship is defined as follows: Capital Recovery Factor = $[i(1+i)^n]/[(1+i)^n - 1]$, where "i" is interest rate and "n" is years for recovery. For comparison, the same cost basis is calculated for a 5-year remaining lifetime, which may reflect the plans of several operators.




Figure 6-1. SCR Retrofit to Coal-Fired Units: Incurred Cost per Ton, 10-Year Basis




Figure 6-2. SCR Retrofit to Coal-Fired Units: Incurred Cost per Ton, 5-Year Basis

Figure 6-2 shows the decrease in lifetime from 10 to 5 years significantly increases cost. The incurred cost for a unit at the median population is projected to be \$31,663 per ton for operation at 56% capacity factor, escalating to approximately \$44,286 per ton for a unit at the 90% population. For operation at the 2021 capacity factor, the analysis shows the cost for the median population to be nearly identical at \$32,286 per ton, while 90% of units in the population will incur a cost not more than approximately \$70,000 per ton. The 5-year lifetime approximately doubles incurred costs.

As described in Section 5, we could not replicate EPA's results. The bulk of the disagreement is likely due to the different database of units, as the additional states included in EPA's analysis incur a 11% lower control cost. A second contributing factor could be the specific mathematical relationship used in SCR capital cost accounting - two were referenced in the TSD.³¹ Additional transparency in how EPA derived these costs is required, and requested from the EPA. Using the Retrofit Cost Analyzer as the calculation method as described in the TSD with EPA's inputs, but confining the analysis to the 25 states, the projected cost at the median population is \$17,508/ton NOx reduced, exceeding EPA's reference case value of \$15,500/ton.

Two factors drive the cost per ton of NOx removed for results in Figures 6-1 and 6-2 – the capital required and the boiler NOx exit rate, the latter determining the NOx tons removed over which amortized capital and operating costs are distributed. Notably, generating units with low boiler NOx emission rates – particularly 0.15 lbs/MBtu or less – incur extremely high costs for NOx control with SCR. Figure 6-3 depicts data from Figure 6-1 as a function of boiler NOx exit rate – showing how cost ranges from \$25,000 to \$35,000 per ton. This cohort of units incurs significant cost penalties to deploy SCR to meet the EPA proposed rule.

6.1.2 Distillate Oil/Natural Gas

SCR retrofit is proposed for oil/gas-fired units 100 MW or greater capacity and that generate more than 150 tons of NOx annually.

Figure 6-4 summarizes results derived in this study for the 35 units in the 25 states which qualified by EPA's criteria to retrofit SCR, based on a 10-year remaining lifetime. Also shown on Figure 6-4 is the cost per ton reported by EPA for their findings on the 35 states, using their assumed input conditions.

Results from this study report the incurred cost for a unit at the median population of \$11,373 per ton for operation at 26% capacity factor, escalating to approximately \$19,000 per ton for units at the 90% population. For operation at the 2021 capacity factor, the analysis shows the cost for the median population to be \$37,754 per ton, escalating to more than \$80,000 per ton.

³¹ EPA is not clear as to whether the SCR Retrofit Cost Analyzer is used, or the relationship described for IPM (Table 5-5 of Chapter 5 Emission Control Technologies.) The difference in these two mathematical relationships -- upon converting to a 2021-dollar basis using EPA's cost adjustment -- is an additional 4%.




Figure 6-3. NOx Removal cost per SCR Retrofit: Role of Boiler Exit NOx Rate

Efforts to replicate EPA's calculation were reasonably successful, as among other factors, EPA's boiler inventory varied little from that used in this study. The cost at the median estimated by this study using EPA's relationships is \$10,426, approximating EPA's published reference.

Figure 6-5 presents results for a 5-year remaining lifetime. Figure 6-4 reports a significant increase in costs. The incurred cost for a unit at the median population is projected to be \$18,429 per ton for operation at 56% capacity factor, escalating to approximately \$32,000 per ton for a unit at the 90% population. For operation at the 2021 capacity factor, the analysis shows the cost for the median population to be \$62,661 per ton, escalating to more than \$80,000 per ton for a unit at the 90% population. The 5-year lifetime increases costs by approximately 30%.




Figure 6-4. SCR Retrofit to Oil/Gas-Fired Units: Incurred Cost per Ton, 10-Year Basis




Figure 6-5. SCR Retrofit to Oil/Gas-Fired Units: Incurred Cost per Ton, 5-Year Basis

6.2 SNCR Retrofit

SNCR retrofit is proposed for both coal-fired units of capacity of 100 MW or less.

Figure 6-5 summarizes results derived in this study for the eight units in the 25 states to which SNCR is proposed for retrofit, based on a 10-year remaining lifetime. This analysis employs the same calculation methodology used by EPA (the S&L Retrofit Cost analyzer) with the exception that costs are escalated to 2021 using the CEPCI.

Results from this study report the incurred cost for a unit at the median population of \$12,645 per ton, for operation at 26% capacity factor as proposed by EPA,³² escalating to more than \$100,000 per ton for a unit at the 90% population. For operation at the 2021 capacity factor, the analysis shows the cost for the median population to be \$67,432 per ton. For these same input conditions and similar unit inventory, EPA reports incurred cost per ton for the median unit as \$7,100/ton.




Figure 6-6. SNCR Retrofit to Coal-Fired Units: Incurred Cost per Ton, 10-Year Basis

Results for a 5-year remaining lifetime (not shown) report incurred costs that escalate by approximately 50%. The incurred cost for a unit at the median population is projected to be \$19,438 per ton for operation at 56% capacity factor, escalating to more than \$100,000 per ton for a unit at the 90% population. For operation at the 2021 capacity factor, the analysis shows the cost for both the median and 90% population exceed \$100,000 per ton.

³² EGU_TSD. Page 23.

6.3 Existing SCR Performance

The NO_x removal costs incurred by enhancing the performance of existing SCR process equipment are presented in this section. These costs are determined using the methodology described in Section 4, and reflect changes to EPA mathematical relationship address elevated catalyst management costs for NO_x removal exceeding 80%, capital to refurbish SCR reactors entering service prior to 2005, and employ the CEPCI to escalate costs (from 2019) to mid-2021.

Figure 6-6 presents results for the study population of 94 units from the 25 states. Data are shown for a 5 and 10-year recovery period for the nominal investment (approximating \$25/kW) for units that entered commercial duty prior to 2005. These results show the median cost is approximately \$14,000-\$15,000 per ton; 90% of units in the population will incur a cost not more than approximately \$40,000 per ton.




Figure 6-7 Incurred Cost per Existing SCR to Achieve 0.08 lbs/MBtu

Figure 6-7 presents the true cost EPA should be using as the metric - the marginal cost for the incremental reduction in NO_x from the 2021 ozone season rate achieved by SCR. Absent EPA actions, this 2021 NO_x rate would continue – thus enhancing SCR performance to meet 0.08 lbs/MBtu (with margin) is an additional benefit. The methodology to determine this cost is the proper approach to value the cost of this aspect of the proposed rule.

EPA does not address the true marginal cost. Rather, EPA focuses on estimating the cost for “re-starting” an “idled unit – an event rarely if ever encountered in practice.”³³ EPA’s analysis employs equations defined in the Retrofit Cost Analyzer to evaluate hypothetical “typical” units, selecting a range of inlet NOx, percent NOx removal, and capacity factor to bound the results. The highest cost projected by EPA using this method is \$2,220 /ton.

6.4 Postcombustion NOx Takeaway

The retrofit of SCR to coal units, if feasible given the schedule constrain, will reduce NOx for a cost of \$20,250 per ton at 56% capacity factor, escalating to approximately \$28,000 per ton for units at the 90% population. These costs increase if estimated using each units’ unique 2021 ozone season capacity factor, or a 5-year recovery period. Almost 100 units (94 evaluated in this study versus 88 evaluated by EPA) units will be required to retrofit SCR. The costs predicted by this study - \$20,250/ton at 56% capacity factor for the median unit in the population – exceed EPA’s estimate of \$15,500/ton by approximately 33%.

Generating units with boiler exit NOx rates of 0.15 lbs/MBtu, if retrofitting SCR, will incur NOx removal cost on a per ton basis that are exorbitant. This study showed generating units in the 25-state region with boiler NOx rates approximating 0.15 lbs/MBtu incurred NOx removal costs of \$25,000 to \$35,000 per ton, based on a 56% capacity factor.

The retrofit of SCR to distillate oil/gas-fired units to 35 “qualifying” units incurs cost for a median unit from \$11,000/ton at 56% capacity factor and 10 year remaining life, to over \$66,000/ton for operation at the 2021 capacity factor and 5 year remaining lifetime.

Increasing NOx removal from existing SCR process equipment – and considering the marginal cost of this action – incurs a median cost of approximately \$15,000/ton, escalating to more than \$40,000/ton for a unit at the 90% population. EPA does not calculate the marginal cost for this action, but rather a cost for “restarting idled units”, which in their evaluation does not exceed \$2,220/ton.

SNCR retrofit as EPA proposes – to coal-fired units of 100 MW generating capacity or less - captures only six units. The incurred cost for the median unit ranges from \$12,645/ton to more than \$100,000/ton, the latter elevated reflecting operation at the 2021 capacity factor and 5 year remaining lifetime. These costs well exceed EPA’s reference basis for SNCR for the population of boilers less than 100 MW of \$10,800/ton for coal application.

³³ See EGU TSD, page 6.

7. Proposed Backstop Daily NO_x Rate

Section 7 address EPA's proposed daily backstop NO_x rate of 0.14 lbs/MBtu. The derivation of this rate as described in the EGU TSD does not account for the inherent variability that even well-maintained SCR reactors encounter.

Operating data from the national fleet of units equipped with SCR provides insight to the variability of operation, particularly during the startup /shutdown events that almost without exception a unit encounters during an ozone season. This analysis considers the NO_x emission trends of 110 units that during the 2021 ozone season operated SCR reactors at high performance levels, meeting the 0.08 lbs/MBtu seasonal average. These data are insightful in terms of the prospect of occasionally exceeding on a daily basis the proposed backstop rate of 0.14 lbs/MBtu

7.1 Background: Startup

Figure 7-1 presents an example timeline for SCR startup, defining the key events over three categories of time. The timeline shows in the initial time period (0-3 hours) how the induced and forced draft fans initiate operation, when coal is introduced and when the flame is stabilized. During the second time period – ranging from 3 to 24 hours – gas temperature leaving the boiler and thus entering the SCR reactor reaches 300-400 °F; and thereafter achieves the minimum temperature at which ammonia reagent can be injected. This minimum temperature varies with many factors, most importantly fuel composition and associated sulfur content, and can be approximately 580 °F for subbituminous coals up to 620 °F for some bituminous coals. At this juncture ammonia reagent is injected, and postcombustion removal of NO_x initiates – limited by the gas temperature and the ‘activity’ of the catalyst for NO_x reduction, as well as limits in mixing. During the third time period – 24+ hours or more – the unit achieves full load and the SCR is able to operate at design values.

Figure 7-1 shows that “Phase 1” of SCR reactor operation initiates when the flue gas minimum operating temperature is attained – at some point within the 3-24 hour period after the coal flame is stabilized. This Phase 1 period persists for 3-6 hours, evolving into Phase 2 as the unit approaches full load – and the reactor gas temperature approaches full load values. The Phase 2 or commercial operating state is attained typically after 6 hours from ammonia in injection.

Figure 7-2 presents a timeline of data observed in May of 2020 from an actual process startup for LG&E/KU Mill Creek Unit 4, a bituminous wall-fired unit. The outage from which Unit 4 is emerging up reflects a typical ‘pre-ozone season’ outage, essential to inspect catalyst and equipment for reagent injection. The NO_x emission rate is recorded through the startup and reflected on the left axis, while the ammonia reagent (gallons/hr), load (MW), and reactor temperature (°F) are reported on the right axis. Also shown is the daily NO_x average, constructed per EPA boiler operating day data.




Figure 7-1. Timeline of Key Events in SCR Process Startup




Figure 7-2. LG&E/KU Mill Creek Unit 4 Startup Data

Figure 7-2 shows that at least for two boiler operating days following ammonia injection, the daily NO_x rate exceeds the proposed backstop value of 0.14 lbs/MBtu. Consistent with Figure 7-2, EPRI reports typical SCR startup periods are 7-24 hours, and impact the ability of the SCR process to effectively remove NO_x.³⁴

Additional insight as to the role of startup on delaying operation of SCR and control of NO_x emissions is reflected data from six startup events experienced by LG&E/KU Trimble County Unit 2, from January 31 2020 to April 28 2021. Figure 7-3 presents a bar chart summarizing the time required for from establishing combustion to (a) “sync” with the power grid, (b) initiate reagent flow, and (c) to achieve 80% NO_x reduction.




Figure 7-3. LG&E/KU Trimble County 2: Time Duration of SCR Startup Events

The key takeaway from Figure 7-3 is the time required for 80% NO_x reduction, which over six startup events ranges from 12 to 25 hours.

Additional experience shared by LG&E/KU with startup of an SCR-equipped unit firing eastern bituminous fuel is insightful. LGE/KU documented elapsed time from firing to ammonia injection of approximately 16 hours for many of their SCR-equipped units, from a cold start under ideal conditions – that is, as long as there were no other equipment failures.³⁵ In some

³⁴ EPRI 3002015872 – Operation and Maintenance Guidelines for Selective Catalytic Reduction Systems, December, 2011.

³⁵ Personal Communication, LG&E and KU Energy LLC Staff: June 15, 2022.

cases, multiple starts are required to address unanticipated issues with ancillary equipment. Some unit startups require longer – a few days – to reach ammonia injection temperatures. Notably, the time to initiate ammonia injection is not up to the discretion of the owner – but specified by the SCR or catalyst supplier.

Although not the focus of this discussion, the “mirror” step of startup - shutdown - can remove SCR from service with the unit continuing to operate for 1-2 hours.

7.2 2021 Inventory Data

NO_x emissions from a subset of units operating at high NO_x removal over the ozone season illustrate how startup/shutdown events affect emissions. For each of the 110 units in the SCR-equipped inventory which emit less than 0.08 lbs/MBtu for the ozone season, the daily NO_x emission rate (per EPA’s definition of a boiler operating day) is calculated. As subsequent data shows, even well-performing units experience daily NO_x emissions exceeding 0.14 lbs/MBtu. Both the number of units for which a daily rate exceeds 0.14 lbs/MBtu and the number of events were recorded. Results are reported in Figures 7-4 to 7-8.

Count of Units with Daily Emissions Above the Proposed Backstop Rate. Figure 7-4 reports for the 110 units that achieved 80% NO_x reduction for the 2021 ozone season, the number of units for which NO_x is observed to exceed the proposed daily rate of 0.14 lbs/MBtu. Figure 7-4 shows about 1/3 of the total units in this population – 36 – do not experience excursions in NO_x daily rate exceeding the proposed 0.14 lbs/MBtu. The horizontal axis describes the increase in units that emit more than 0.14 lbs/MBtu, for multiple days. For example, eleven units operated above 0.14 lbs/MBtu for three days, while five units exceed that rate for 7 days.

Count of Units with Startup Days. Figure 7-5 reports the number of units that experienced a startup in the 2021 ozone season, ranging from none (“0”) to 13 days. Figure 7-5 shows only 6 units did not encounter any startup days. The largest number of units – 21 – encountered three startup days, while three units encountered 10 startup days.

Count of Units per Hours of Outage. Figure 7-6 reports the number of units that experience outages of at least one hour a day – necessitating as a minimum a “hot” startup. Figure 7-6 describes the wide range of outage days incurred by the 110 units that achieved the 2021 ozone season limit of 0.08 lbs/MBtu.

Figure 7-6 shows the median unit encountered 27 days of the 153-day season – almost 20% - affected by an outage (requiring at least one startup and affecting NO_x emissions). The units that were least influenced by outages – units at the 10% of the study population – experienced four days affected by an outage. Conversely, units most influenced by outages – units at the 90% percentile - encountered 76 days.




Figure 7-4. Count of Units Emitting Above Proposed Backstop Rate




Figure 7-5. Role of Startup days on Count of Units Emitting Above Proposed Backstop Rate




Figure 7-6. Count of Units Experiencing at Least One Hour of Outage




Figure 7-7. Role of Days Following Startup on Days Exceeding Daily Rate

Role of Days Following Startup. The operating time subsequent to a startup is one indicator potential for daily rate exceedances. Figure 7-7 presents data derived from the inventory of units operating over the 153 day 2021 ozone season, describing the number of days that exceed the proposed daily backstop rate.

Figure 7-7 shows operating within 1 full day of startup, a total of 65 observed days were recorded with NO_x exceeding the 0.14 lbs/MBtu rate. But within a second day the observed days exceeding 0.15 was dropped by 1/3, to 21 total days. After 4 days such observations are negligible.

Role of Load. Operating load affects performance of the SCR process, with load less than 40% frequently inducing boiler outlet gas temperature below the minimum operating temperature for ammonia injection. At these conditions reagent is typically terminated to prevent possible catalyst damage from residual ammonia emissions.

Fossil-fuel generating units are presently under pressure to increase –not decrease - flexibility to operate for extended periods at low load to balance the grid and compensate for variable renewable generation. The need for coal-fired units to consistently operate at loads where SCR operation either is not optimal or must be terminated will increase, and not decrease, in future years. Retrofitting SCR limits the flexibility of coal-fired units to provide variable load.

Figure 7-8 reports the cumulative number of days that all units in the 110-unit study population exceeded the proposed backstop rate of 0.14 lbs/MBtu for the 2021 ozone season. The left axis reflects the fraction of total operating days in each load “bin” that exceeded the proposed backstop rate. For example, over the 2021 ozone season, units operating at or below the 20% load “bin” recorded a total of 390 days exceeding the proposed backstop rate – equal to 47% of operating days in that load bin. A similar number of operating days – 370 – were recorded for all units operating in the 21-40% bin with NO_x exceeding the proposal backstop rate, comprising 12% of all operating days in that bin.

The combined operating time for these two low load categories – 756 days – represents conditions where SCR is not operating in an optimal state, or must be terminated as inlet gas temperature is below the minimum required for injection. At these conditions, the generating units operate with no material postcombustion control of NO_x emissions. Conversely, above 80% load, 6,971 operating days were recorded with NO_x emissions less than 0.14 lbs/MBtu.




Figure 7-8. Role of Load Factor

These data show units in the select boiler population which meets the 0.08 lbs/MBtu limit, it is almost unavoidable to incur an outage and thus startup that causes a unit to emit more than 0.14 lbs/MBtu. Even altering the definition of how the rate is calculated - from a daily rate to a short-term, multi-day rate such as an average of 2 or 3 days –leaves significant number of operating events exceeding the 0.14 lbs/MBtu rate.

Table 7-1 compares the “count” of units that exceed the 0.14 lbs/MBtu proposed daily rate and the total number of days in which exceedances are observed – for three averaging methods. Table 7-1 shows the scope of lost operating time, with and without startup. There are no periods where a unit experiences startup/shutdown and does not exceed the proposed backstop rate.

Two observations are clear from Table 7-1. First, altering the calculation to consider a 2- or 3-day average lowers the count of units that experience exceedances, and the total count of exceedances – but does not eliminate them. Even if the EPA were to revise the proposal to employ a 3-day averaging period, a relatively large number of exceedances would still occur. In this data set, 62 are experienced by 24 units.

Second, it is unavoidable units will have outages – even eliminating the role of startup, there are unavoidable outage days for each averaging period that would prompt NO_x emissions to exceed the proposed backstop rate.

Table 7-1. Units, Exceedances of Exceeding Proposed Backstop Rate of 0.14 lbs/MBtu

Proposal Rule Structure	Count of Units with Exceedances	Total Number of Exceedances
1-Day Average: with SU/SD	74	317
1-Day Outage: without SU/SD	52	183
1-Day Average: with SU/SD	53	149
1-Day Average: without SU/SD	22	46
1-Day Average: with SU/SD	24	62
1-Day Outage: without SU/SD	9	21

Longer averaging times do eliminate exceedances – specifically, calculating the 30-day average resulted eliminated any exceedances, even including startup/shutdown.

7.3 Takeaway

The introduction of a daily backstop rate – at the proposed value of 0.14 lbs/MBtu - will prompt even units with well-run SCR processes into exceedances, mostly due to unavoidable startup operation. An increase in averaging times to 3 day averaging period does not alleviate the considerable restriction that the daily backstop rate would impose. Imposing such a backstop will change the way units operate – and could compromise achieving the targeted NO_x outlet rate of 0.08 or 0.05 lbs/MBtu. Specifically, an equipment malfunction – such as inadequate control over reagent injection - if left uncorrected to avoid a shutdown and exceeding the backstop rate, could compromise SCR operation at full load.

It should be noted owners are restricted in startup to abide by recommendations imposed by boiler and steam turbine suppliers. Specifically, the unit ‘ramp rate’ – the rate at which electricity generation can be increased and operating temperature of the SCR reactor attained – is defined by the SCR and catalyst supplier, and the steam turbine. The cost consequences of accelerating startup to minimize exceeding the backstop rate could damage steam turbine precision moving parts, incurring significant repair cost.

8. Generation Shifting

EPA proposes Generation Shifting as a means for NO_x control, augmenting the proposed actions described in the previous sections. EPA considers Generation Shifting a step in establishing the State Budget Setting process- thus as a control step. Consequently, EPA's methodology for Generation Shifting is described here immediately subsequent to control technology.

The nine states selected to identify, evaluate and demonstrate issues with EPA's approach are: Arkansas, Indiana, Kentucky, Missouri, Ohio, Pennsylvania, Texas, West Virginia, and Wyoming. Generation Shifting occur not only with transport region program units but also non-program units such as, renewables, landfill gas, reciprocating units, and non-fossil capacity.³⁶ In some states, a generation unit may have an equal reduction to an increase in generation, e.g., modeled as having the same GWh value produced from different sources. Therefore, units that contribute equally to loss and gain ("cancel") are not included in the generation shifting charts but are included in the overall Total GWh produced and NO_x tons emitted per state.

EPA uses Generation Shifting to bias generation and NO_x emissions from higher to lower NO_x emitting sources. EPA uses the IPM where EPA's v6 models' regional breakdowns of net energy for load in each of the 67 IPM U.S. regions presented in the Figure 8-1.³⁷

Generation Shifting is the third and final step in determining state budgets. Generation shifting is quantified by three IPM runs – Base Case, Run 1 and Run 2. The Base Case is the Integrated Planning Model (IPM) Summer 2021 Reference Case, while Run 1 represents base case optimization and LNB upgrade and Run 2 represents \$1,800 per ton threshold. The Summer 2021 Reference Case is based upon electrical demand from EIA's Annual Energy Outlook 2020 and specific fuel prices and technology costs outlined IPM's most recent documentation.³⁸ In addition to these IPM runs, EPA adds a further calculation which determines the differential NO_x emission rates between average IPM emission rates and Engineering Analytics emission rates. The minimum of these differential rates is applied to a state heat input to derive emission reductions, which are subtracted from the Optimized Baseline to yield a final state budget.

EPA's description of Generation Shifting is inadequate, and lacks of transparency on the steps and data used. Given the significance of Generation Shifting in affecting state budgets in some states, it is critical that EPA clearly explain how this step is down.

³⁶ Non-Program units are not regulated by the proposal and do not contribute to the state budget or receive allowances. Non-Fossil do not qualify as biomass, but include waste products of liquid and gaseous renewable fuels.

³⁷ Figure 3-1 from EPA document. Available at: https://www.epa.gov/sites/default/files/2019-03/documents/chapter_3_0.pdf

³⁸ Documentation for EPA's Power Sector Modeling Platform v6: Using the Integrated Planning Model, September 2021.




Figure 8-1. IPM Model: Definition of 67 Modeling Regions

8.1 Overview of Findings

Specific issues are identified and discussed addressing how shifting is used in state budgets. Generation Shifting is quantified by three IPM runs – Base Case, Run 1 and Run 2.

The Project Team only considered at generation shifting in 2023, since EPA indicated that by the 2025 budget year heat input should reflect such shifting in generation.³⁹ Of the three IPM runs that establish Generation Shifting results, the Base Case as the foundation is the most critical. However, the Base Case is flawed in that it does not represent the generating unit profile in many of the 25 states that comprise the proposed Transport Rule region.

Specifically, within the nine example states addressed in this analysis, in 2023 IPM erroneously retired 32 coal units representing 9.7 GW of capacity. None of the owners of these 32 units have announced retirement for 2023; notably 9 units totaling 6.6 GW are SCR-equipped and thus are expected to contribute to low NOx emissions. IPM also in 2023 idled 42 coal units representing 14.9 GW, also significant capacity with low NOx emissions. These 42 coal units that are idled by IPM do not generate any electricity in 2023. In regard to this outcome, NRECA previously

³⁹ 87 Fed Reg 20108.

expressed concern to EPA that IPM modeling does not capture the true cost of idling. Of these 42 units, 17 are SCR-equipped and represent 8.5 GW, despite featuring an average ozone season NO_x rate of 0.07 lbs/MBtu. In addition, IPM idles an additional 14 coal units representing 7.4 GW of coal capacity during the 2023 ozone season.

Table 8-1 presents the coal capacity by state that EPA has either retired or idled in the nine example states evaluated. The table indicates that IPM has slightly over 28 percent of the operable coal capacity idled in the nine-state study region during the 2023 Ozone Season.

Table 8-1. IPM 2023 Retired and Idled Coal Capacity in the Nine-State Study Region (MW)

State	IPM Operable Coal Capacity	IPM Year-Round Idled Capacity	IPM Ozone Season Idled Capacity	IPM Retired Coal Capacity
AR	5,105	1,817	0	0
IN	11,147	1,118	4,252	0
KY	8,890	1,286	1,017	0
MO	9,417	275	0	240
OH	10,163	136	751	0
PA	1,964	112	767	6,958
TX	17,534	9,632	0	0
WV	11,220	520	80	0
WY	3,830	0	530	2,505
TOTAL	79,270	14,896	7,397	9,703

The flaws in the Base Case generation profile impart flaws in results from Run 1 and Run 2 (derived from the Base Case) that cannot accurately represent shifting of generation within a state. Specifically, EPA projects generation shifted to non-regulated sources (e.g., sources not covered in the Transport Rule), such as renewables, non-fossil, storage and industrial facilities as a consequence of eliminating low NO_x emitting coal units due to retirements and idling. Most of these non-regulated sources are non-dispatchable facilities/units that cannot perform on demand.⁴⁰ This is particularly true for storage capacity, which is not a generating source and cannot provide enough electricity during the peak event. This becomes a major flaw in the modeling and can be attributed to the flaws in the Base Case. It should be noted, if a facility/unit is not shown, there was no shifting in generation modeled for that unit. Specifically, the facility/unit did not increase or decrease its generation in 2023.

Perhaps the most notable concern is EPA's erroneous assumption of unrestricted transfer of generation across a state, particularly so for states with multiple RTOs. EPA and IPM do not consider transmission constraints and the associated reliability issues that can occur during the height of the ozone season.

⁴⁰ A non-dispatchable source of generates electrical energy but cannot be turned on or off in order to meet demand. It is the opposite of dispatchable sources of electricity which flexible and able to change output quickly to meet electricity demands.

The Project Team recommends EPA eliminate the Generation Shifting step in the State Budget setting process and only use the Optimized Baseline values as the final state budget numbers.

Finally, EPA's Budget Setting Engineering Analytics and IPM Policy Case in 2026 NO_x reduction potential are in conflict. EPA estimates 64,000 tons NO_x reduction potential in 2026 from 42 GW of SCR retrofits on coal and 19 GW of SCR retrofits on oil/gas steam units. However, IPM projects a 47,000 tons NO_x reduction in 2026 from 32 GW of EGU capacity being retrofitted with SCRs. This disconnect can be attributed the flawed IPM Base Case, which does not represent an accurate generation profile in the affected states.

Summary charts, are based upon the three IPM RPE output files for 2023 that can be found in the proposed rule's docket and that illustrates Generation Shifting in each of the nine states. Appendix A presents a map for each of the nine states identifying the location of the major generation sources for which Generation Shifting either increases or decreases generation output.

8.2 Arkansas

Figure 8-2 summarizes the generation-shifting in Arkansas, resultant to 3 IPM regions identified as MISO Arkansas, SERC Delta AECL, and SPP West (Oklahoma, Arkansas, Louisiana). The modeled runs are based on a total of 27,807 GWh of generation in Arkansas for 2023. Ten units are identified as part of generation shifting. Increases in GWh are primarily from the combined cycle Dell Power Station in SERC. Generation losses are solely from MISO. An Arkansas state map in Appendix A identifies the locations of the most significant sources affected.




Figure 8-2. Generation Shifting Summary: Arkansas

Four units surrender generation: two coal (Independence Units 1, 2; White Bluff 2), one combined cycle (Harry L. Oswald), and a non-fossil unit. Non-program capacity pumped storage and Paragould Reciprocating pick up generation, which are non-dispatchable and not able to perform on demand. The generation shift of 71 GWh results in a reduction of 30 tons of NO_x.

8.3 Indiana

Figure 8-3 summarizes the generation-shifting in Indiana, resultant from two IPM regions - MISO Indiana (including parts of Kentucky) and PJM West. The modeled runs are based on a total of 36,894 GWh generation in Indiana for 2023. All generation shifts occur within MISO. Sixteen units are identified as part of the generation shifting. Five units included have a generation net gain from Gibson 1-3, Gibson 5, Clifty Creek 4-5, Michigan City and Warrick 4, with a net loss from Warrick 1-3 and Clifty Creek 6. Since IPM idled 5.3 GW of Indiana coal capacity, to squeeze out additional NO_x tons, IPM reduced generation from three non-program units, Warrick 1-3. The generation shift of 318 GWh results in a reduction of 335 tons of NO_x. An Indiana state map in Appendix A Identifies the locations of the most significant sources affected.




Figure 8-3. Generation Shifting Summary: Indiana

8.4 Kentucky

Figure 8-4 summarizes the generation-shifting in Kentucky, considering four IPM regions in—MISO Indiana (including parts of Kentucky), PJM West, SERC Central Kentucky, and SERC Central TVA. The modeled runs are based on a total generation of 26,254 GWh in Kentucky for 2023. There is a net loss in PJM and SERC Central Kentucky, with the greatest net gain in MISO. Twenty-one units are identified as part of the generation shifting. Non-program units include a landfill gas facility which is non-dispatchable. A Kentucky state map in Appendix A identifies the locations of the most significant sources affected.




Figure 8-4. Generation Shifting Summary: Kentucky

IPM idled 2.4 GW of Kentucky coal capacity in 2023, many of which had post-combustion controls. As a consequence of this idling, IPM idled both RD Green 1/2 (MISO) and Big Sandy (PJM), and brought on-line during the ozone season a low emitting coal unit – DB Wilson (MISO)- to offset generation, resulting in generation being shifted between two RTOs. The generation shift of 1,576 GWh results in a reduction of 1,138 tons of NOx.

8.5 Missouri

Figure 8-5 summarizes generation-shifting in Missouri, based on the four IPM regions of MISO Missouri, SERC Delta AECI, SPP North (Kansas, Missouri), and SPP West (Oklahoma, Arkansas, Louisiana). The modeled runs are based on a total generation of 35,627 GWh in Missouri in 2023. Loss in generation occurs only in MISO.




Figure 8-5. Generation Shifting Summary: Missouri

The major reduction is from Sioux 1-2, which is idled by IPM during the 2023 ozone season. Thirty-eight units are identified as part of the generation shifting. Non-program units include an energy and pump storage, both non-dispatchable. The generation shift of 998 GWh results in a reduction of 971 tons of NOx and cuts across SERC, MISO and SPP. A Missouri state map in Appendix A identifies the locations of the most significant sources affected.

8.6 Ohio

Figure 8-6 summarizes generation-shifting in Ohio, based on the IPM regions PJM ATSI and PJM West. The modeled runs are based on a total generation of 60,358 GWh in Ohio for 2023. The net reduction in PJM West of 529 GWh is balanced by the net increase in PJM ATSI.

Twenty-one units are identified as part of the generation shifting in Ohio, with WH Sammis 5 being idled in the ozone season. IPM includes three non-program, non-dispatchable resources – two non-fossil facilities and one biomass facility. The generation shift of 1,188 GWh results in a reduction of 717 tons of NOx. A Ohio state map in Appendix A identifies the locations of the most significant sources affected.




Figure 8-6. Generation Shifting Summary: Ohio

8.7 Pennsylvania

Figure 8-7 summarizes generation-shifting in Pennsylvania, across six IPM regions, all of which are within PJM. These are: AP, ATSI, EMAAC, PENELEC, West, and Western MAAC. The modeled runs are based on a total of 108,258 GWh in 2023, of which 12,499 GWh from PJM ATSI and PJM West do not contribute to the generation shifting. Net losses occur in Western MAAC and PENELEC, with increases AP and EMAAC. Twelve units are identified as part of the generation shifting, with two non-program, non-dispatchable resources (energy and pumped storage) are involved in picking up additional generation. One of the main contributing factors to the results in Pennsylvania, is that IPM retired almost 7.0 GW of coal capacity in 2023. The generation shift of 254 GWh results in a reduction of 3 tons of NOx. A Pennsylvania state map in Appendix A identifies the locations of the most significant sources affected.




Figure 8-7. Generation Shifting Summary: Pennsylvania

8.8 Texas

The four main regions in Texas are ERCOT, MISO WOTAB (including Western), SPP, and WECC New Mexico. The IPM regions for SPP include SPS (Texas Panhandle) and West (Oklahoma, Arkansas, Louisiana). The IPM regions for ERCOT include the following five: Panhandle, Rest, Tenaska Frontier Generating Station (Frontier), Tenaska Gateway Generating Station (Gateway), and West. The modeled runs are based on a total generation of 217,853 GWh in the state for 2023, of which 187,971 GWh are from two IPM ERCOT regions (Rest, West). The other three ERCOT regions do not contribute to the generation shifting. SPP contributes 15,404 GWh, MISO contributes 11,835 GWh, and WECC 2,643 GWh. Statewide, fifty-eight units participate in generation shifting. Non-program, non-dispatchable units include biomass and storage units. The Texas-wide generation shift of 2,435 GWh reduces 1,034 tons of NOx.

Three figures are presented for Texas. Figure 8-8 summarizes generation shifting across the four main regions. EPA's Generation Shifting strategy involves ERCOT and non-ERCOT regions. IPM models SPP losing up to 40.3 GWh of generation in 2023 and ERCOT gaining 25.1 GWh of generation, with MISO and WECC gaining 4.2 GWh and 11.0 GWh, respectively. This modeled generation shift presents a major flaw. Specifically, generation from ERCOT cannot transfer to SPP and only ERCOT can shift generation within ERCOT. Another modeling issue is the CT capacity acquiring generation - CTs are generally designed to produce at peak only. CTs may not have sufficient authorization for operation at higher rates for additional emissions. Figures 8-9 and 8-10 separate ERCOT and non-ERCOT regions, respectively. A Texas state map in Appendix A identifies the locations of the most significant sources affected.




Figure 8-8. Generation Shifting Summary: Texas




Figure 8-9. Generation Shifting Summary: Texas, ERCOT




Figure 8-10. Generation Shifting Summary: Texas, Non-ERCOT

8.9 West Virginia

Figure 8-11 summarizes generation-shifting in West Virginia, based on West Virginia IPM regions PJM AP and PJM West, which are all within PJM. The modeled runs are based on a total of 26,717 GWh in West Virginia for 2023. The net reduction in PJM AP of 777 GWh is directly balanced out by the net increase in PJM West. Five units are identified as part of the generation shifting. Modeled generation loss is primarily from idling Fort Martin Power 2 during the ozone season. The generation shift of 1,124 GWh results in a reduction of 1,123 tons of NOx. A West Virginia state map in Appendix A identifies the locations of the most significant sources affected.




Figure 8-11. Generation Shifting Summary: West Virginia

8.10 Wyoming

Figure 8-12 summarizes generation-shifting for the sole IPM region in Wyoming - WECC Wyoming. The modeled runs are based on a total of 14,013 GWh of generation in Wyoming for 2023. Generation reductions are mainly from Laramie River Station (LRS) 2 and 3, two non-SCR units, with Jim Bridger 4 proving the majority of generation increases. Eight units are identified as part of the generation shifting including a non-program CT - Arvada-Barber Creek-Hartzog. The generation shift of 1,090 GWh results in a reduction of 460 tons of NOx. A Wyoming state map in Appendix A identifies the locations of the most significant sources affected.




Figure 8-12. Generation Shifting Summary: Wyoming

The implications of faulty IPM modeling related to Generation Shifting on individual state distorts the assignment of allowance allocations within the nine states. Table 8-2 summarizes the Generation Shifting step has cost the nine states 6,054 allowances.

Table 8-2. Allowances Lost to Generation Shifting in 2023

State	Allowances Lost
AR	38
IN	335
KY	1,213
MO	668
OH	765
PA	409
TX	1,422
WV	828
WY	376
TOTAL	6,054

9. State Budgets, Emissions Allocations, and Reliability

Section 9 addresses issues related to the state budgets for the 25-state proposed Transport Rule, and the impact of assigned state budgets on allowance allocation and reliability.

9.1 State Budget Setting Process

EPA’s State Budget Setting Process under the proposed Transport Rule contains numerous errors and omissions, and adopts incorrect assumptions pertaining to technology deployment and NOx emission rates.

The Project Team selected as examples nine states within the 25-state Transport Rule region to evaluate; however, EPA needs to review all the state budget setting process to ensure the accuracy of the budget process. These states selected for sample analysis - Arkansas, Indiana, Kentucky, Missouri, Ohio, Pennsylvania, Texas, West Virginia and Wyoming – represent different geographic sectors of the Transport Region. These states also represent various RTOs and different utility structures (IOUs, Public Power and Cooperatives).

9.1.1 Identification of Errors and Omissions

EPA’s Budget Setting Process did not accurately assign NOx emission rates to SCR and non-SCR units sharing a common stack. Table 9-1 lists those SCR-equipped units in both Indiana and Kentucky that share a common stack with non-SCR-equipped units, as determined from discussions with unit operators.

Table 9-1. 2021 Unit Emission SCR Emission Rates (lbs/MBtu)

Unit	2021 SCR Rates (lbs/MBtu)
Clifty Creek 4 and 5	0.07
Ghent 3	0.021
Cooper 2	0.06
Shawnee 1	0.048
Shawnee 4	0.062

Correcting NOx emissions from SCR-equipped units to a lower value increases the NOx tons assigned to the non-SCR-equipped unit, as total common stack emissions must remain the same. If the non-SCR-equipped unit features state-of-the-art combustion controls, any such revision of assigned NOx tons increases the budget for 2024 and forward years. If the non-SCR-equipped unit does not have state-of-the-art combustion controls, the 2024 and forward NOx emissions are adjusted based upon retrofitting the unit with a state-of-the-art emission factor.

EPA’s Budget Setting Process did not accurately reflect natural gas conversions in the nine-state study region and it is anticipated that EPA has made similar errors in the remaining states to

covered by the proposed rule. EPA either did not correctly identify the timing of a natural gas conversion or utilize the appropriate post-conversion NO_x emission rate in the State Budget Setting process. Table 9-2 lists units for which conversion to natural gas is planned for which EPA needs to adjust the timing or emission rates in the State Budget Setting process.

Table 9-2. Natural Conversions in the Nine State Study Area

State	Unit	Change
KY	RD Green 1 & 2	Change unit emission rates of 0.17 for 2023
PA	Brunner Island 1-3	Begin burning only gas between May and September in 2023 to generate 0.15 lbs/MBtu
PA	Montour 1 & 2	Possible conversion to natural gas in 2025 at an emission rate of 0.04 lbs/MBtu
WY	Jim Bridger 1 & 2	Conversion to natural gas in 2024 at emission rates of 0.09 (Unit 1) and 0.084 (Unit 2) lbs/MBtu
WY	Neil Simpson II (001)	Conversion to natural gas in 2025 at an emission rate of 0.075 lbs/MBtu

EPA also incorrectly assumes several unit retirements dates which significantly affect a state budget. Table 9-3 lists corrections required to remedy errors in retirement dates.

Table 9-3. Retirement Date Changes in the Nine State Study Area

State	Unit	Change
IN	Merom 1 & 2	Hoosier sold the plant to Hallador Power, which expects to operate beyond 2027
IN	Schahfer 17 & 18	NIPSCO delaying retirement until 2025, as replacement capacity could not be acquired
MO	Rush Island 1 & 2	To be retired in 2024
WY	Naughton 1 & 2	To be retired in 2025
WV	Pleasants 1 & 2	To be retired in 2023

9.1.2 Technology Assignment Issues

In reviewing unit information with owners, the Project Team identified incorrect technology inventory data that need to be addressed in determining final state budgets. Table 9-4 presents examples of EPA's errors in technology inventory.

Table 9-4. Technology Assignment Issues in the Nine State Study Area

State	Unit	Change
IN	Whitewater Valley 1 & 2	Does not have an operating SNCR
KY	Bluegrass Generating Units 1,2 &3	Not equipped with SCR
KY	Cane Run CC	Not equipped with SCR
MO	Sikeston Unit 1	Not equipped with SNCR
MO	John Twitty CT1A	Not equipped with SCR
OH	AMP Gas Turbines	Uses default emission factors in 75.19 as a Low Mass Emitting (LME) unit
PA	Helix Ironwood	Not equipped with SCR
PA	Seward	The plant operated SNCR in the 2021 Ozone Season
TX	Newman GT6A	Not equipped with SCR
TX	San Miguel	The unit operated SNCR in the 2021 Ozone Season
TX	Silas Ray 9	Not equipped with SCR

9.1.3 Technology Deployment Issues

As discussed in Section 4, the timing for installation of Combustion Controls and SCR processes should be revised to determine state budgets in 2023 and 2026. Specifically, Combustion Controls require on average 22 months from project inception to commercial operation, and thus will not be available for the 2023 Ozone Season (see Section 4.5). The earliest time for which Combustion Controls could be operational is the 2024 Ozone Season, which is consistent with the language in the proposal that says state-of-the-art combustion controls are to be readily available at the start of the 2024 ozone season⁴¹. This is contrary to how EPA established the 2023 state budgets, which assumed the availability of combustion controls in 2023. New SCR retrofits will require 40 months on average, and thus will not be broadly available until the 2027 Ozone Season (per information from 18 SCR installations reported in Section 5.3). In calculating the state budgets for 2023, EPA should revise its methodology and not presume Combustion Controls will be operating until the 2024 Ozone Season, and SCR will not be broadly available until the 2027 Ozone Season.

EPA uses a single emission rate for Combustion Controls (0.199 lbs/MBtu) and thus fails to consider fuel and boiler type, which as discussed in Section 4 assert a significant impact on achievable NO_x emission rate. Table 9-5 presents achievable NO_x emissions on a fleet average basis, and should be used in establishing emissions attributed to the 2024 budget year.

⁴¹ 87 Fed Reg 20079.

Table 9-5. Average Achievable NO_x Emission Rates (lbs/MBtu)

Coal Rank	Tangential-Fired	Wall-Fired
Bituminous	0.28	0.32
Lignite	0.20	0.22
Subbituminous	0.15	0.19

In addition to issues related to the calculation of state budgets, EPA has incorporated in Appendix A of the *Ozone Transport Policy Analysis Proposed Rule TSD* each units' gross generation and generating capacity, and computed capacity factors. Although the description of Appendix A material is incomplete, it appears capacity values are reported on the basis of *summer net*, implying an appropriate capacity factor that requires knowledge of net and not gross generation. The Project Team could not reproduce capacity factors listed in Appendix A. The inability to corroborate EPA's calculations creates concerns Appendix A data does not correctly establish the threshold NO_x emission rate of 150 tons per year that determines if oil/gas-fired units are required to deploy SCR.

9.1.4 Recalculation of State Budgets

Based upon issues and omissions identified, EPA should review and adjust all state budgets beginning with budget year 2023. The focus of these adjustments should reflect: (i) the timing for installation of Combustion Controls in 2024 and retrofit of SCR in 2027; and, (ii) the correct technology inventory, and (iii) accurate NO_x emission rates and retirements.

The Project Team recalculated budgets for the nine example states based upon the information described in Section 9.1 for the years 2023 and 2026. Table 9-6 compares the Optimized Baseline developed by EPA in the proposal to a Recalculated Optimized Baseline. The Optimized Baseline consists of retirements, natural gas conversions, and new SCR processes installed prior to the budget year, plus adjustments to the baseline from SCR and SNCR Optimization and Combustion Controls.

Table 9-6 contrasts the Optimized Baselines for each state - the state budgets under the proposed Transport Rule. The Generation Shifting step of the State Budget Setting process should be eliminated, which is discussed in Section 8.

Utilizing the revised timing and technology/retirement adjustments will increase Optimized Baseline values; thereby increasing state budgets for each of the nine states in both 2023 and 2026. The Project Team recommends EPA evaluate each state and employ the type of adjustments identified and revise the state budgets.

Of particular note, EPA is presenting inconsistent data or has erred in estimating the tons of NO_x reduced in the nine states that are attributed to 2023 generation shifting. These discrepancies appear in the table below and are from Proposed Appendix A Proposed Rule State Budget Calculations and Engineering Analytics Spreadsheet and Appendix D-1 of the *Ozone Transport Policy Analysis Proposed Rule TSD*.

Table 9-6. Recalculated State Optimized Baselines: 2023 and 2026

State	Year	Optimized Baseline (Ozone Season Tons)	State Budget (Ozone Season Tons)	Recalculated Optimized Baseline (Ozone Season Tons)
AR	2023	8,927	8,889	8,927
	2026	4,031	3,923	8,702
IN	2023	11,486	11,151	12,556
	2026	7,997	7,791	9,033
KY	2023	12,853	11,640	14,182
	2026	7,761	7,573	12,681
MO	2023	12,525	11,857	12,531
	2026	7,373	7,246	11,047
OH	2023	9,134	8,369	9,140
	2026	8,941	8,586	9,089
PA	2023	9,264	8,855	8,675
	2026	7,228	6,819	8,448
TX	2023	39,706	38,284	39,752
	2026	23,369	21,946	35,842
WV	2023	13,306	12,478	13,849
	2026	11,026	10,597	12,452
WY	2023	9,501	9,125	11,607
	2026	4,580	4,490	8,635

Table 9-7 shows six of the nine states exhibited discrepancies in the role of generation shifting, based on comparing the two sources. These discrepancies further reinforce the argument that the generation shifting step in the State Budget Setting process should be eliminated.

Table 9-7. 2023 Generation Shifting Discrepancies

State	Appendix A Budget Shifting Tons	Appendix D-1 Budget Shifting Tons
AR	38	38
IN	335	326
KY	1,213	1,213
MO	668	444
OH	765	765
PA	409	309
TX	1,422	1,190
WV	828	547
WY	376	958

9.1.5 Non-SCR Unit Retirements between 2026 and 2030

Utility owners are planning to retire or cease firing coal at 29 non-SCR-equipped coal units between 2026 and 2030, representing 17.8 GW of capacity in the 25 State Transport Region (See Appendix A). These units should be exempted from the Backstop Emission Rate of 0.14 lbs/MBtu. Since there will be no NO_x emissions when they retire, for budget setting purposes their emission rate for the 2026 thru 2030 budget years should be based upon the optimization of current controls.

9.1.6 2021 Baseline

The State Budget Setting process employs data at one point in time - 2021 – to project state budgets for 2023 and 2024. This approach is flawed as future electric utility operations based upon one historical year will not represent volatility in fuel prices and demand. This static approach does not account for changing dispatch conditions and unit performance, specifically changes in load. For example, a unit may meet EPA's mandated emission rate at a particular point in time, based on historical heat input which will not reflect future unit operations – which could be compromised due to greater operating duty at minimum load. This static approach also commits units to a fixed capacity factor for state budget purposes. EPA should consider an alternative approach that consider changes in demand in computing individual state budgets.

9.2 Emission Allowances and Reliability

The major concern of electric generators beginning in 2023 is their ability to meet demand and insure system reliability under the proposed rule's state allowance allocation system. As shown in Table 9-8, many electric generating units will not be able to comply with their allowance allocations in 2023.⁴² More specifically, looking at the nine example states addressed in this evaluation, the Project Team estimated an overall allowance shortfall of 6,310 allowances during 2023 Ozone Season.

⁴² Generation forecast was based upon EIA's AEO22 regional electric generation forecasts by fuel type and takes into account retirements, technology deployment schedules and EPA mandated technology emission rates for SCR-equipped units. The 2023 allowances assume a redistribution of unused New Source Set-Aside allowances.

Table 9-8. EGU 2023 Ozone Season Emission and Allocations by State

State	2021 Ozone Season Emissions	2023 Ozone Season Emissions	2023 Allocations	Deficit/Overage
AR	8,955	8,047	8,889	842
IN	14,162	12,595	11,111	-1,484
KY	14,571	14,146	11,640	-2,506
MO	20,388	11,705	11,857	152
OH	11,728	9,961	8,077	-1,884
PA	12,792	8,488	8,782	294
TX	42,760	37,595	38,206	611
WV	14,686	13,607	12,478	-1,129
WY	11,643	10,331	9,125	-1,206
Total	151,684	127,615	120,165	-6,310

Surplus allowances – where estimated for some states - are extremely limited in supply, leaving negligible margin for unforeseen events. The limited allowance market implies allowance purchase will be costly. Consequently, EPA may consider establishing a “Price Ceiling” for such allowances, similar to the structure of the allowances managed for the California Cap-and-Trade Program for CO₂.⁴³

One additional evaluation by the Project Team considered the 2026 Ozone Season emissions and allocations for Kentucky and Texas, as shown in Table 9-9.

Table 9-9. Electric Generating Unit 2026 Ozone Season Emissions and Allocations

State	2021 Ozone Season Emissions	2026 Ozone Season Emissions	2026 Allocations	Deficit/Overage
KY	14,571	11,794	7,675	-4,119
TX	42,760	30,975	22,195	-8,780

A revision of EPA’s budget-setting methodology is required to address this potential negative impact in reliability.

Table 9-9 shows Kentucky and Texas experience significant allowance shortfalls in 2026, even with decreasing ozone season emissions. The 2026 Effective Allowance Emission Rate for both Kentucky and Texas is expected to be 0.048 lbs/MBtu and 0.028 lbs/MBtu, respectively.⁴⁴ These Effective Allowance Emission Rates, along with the allowance shortfall in each state will

⁴³ <https://ww2.arb.ca.gov/our-work/programs/cap-and-trade-program/cost-containment-information/price-ceiling-information>

⁴⁴ The 2026 ozone season emission levels in both Kentucky and Texas assume retrofit SCRs would not be operable until the 2027 ozone season and 2026 allowances assume a redistribution of unused New Source Set-Aside allowances.

constrain how electric utilities will meet demand during the 2026 ozone season. Some utilities may have to constrain operation of coal units, possibly by idling during the ozone season or operating at limited output. These limitations on unit operations can be traced to how the state budgets are determined, such as employing a single year to predict the future thereby locking units into a specific capacity factor. Any limits on unit operation due to allowance shortfalls - with already tight reserve margins – will prompt reliability issues.

An additional reliability issue could result from the approximate 79 units representing 42 GW of coal-fired capacity in the 25-state Transport Region required to retrofit SCR in 2026. Texas and Kentucky alone have 25 units representing 11.8 GW of coal capacity, almost 30 percent of the affected inventory. Many of these units could be forced into retirement in the next four years due to the punitive economics of retrofitting SCR.

Finally, reliability concerns – discussed subsequently - have been identified in the Western half of the United States for the 2022 summer. The proposed Transport Rule could exacerbate these issues for operation in the 2023 ozone season. Specifically:

ERCOT

- ERCOT is forecasting record summer demand in Texas but is confident of capacity. However, ERCOT told Calpine to delay its scheduled repairs and keep plants operating to meet the demand in the hotter-than-expected May. On May 13, a malfunction removed a Calpine unit from service; by 5 PM of May 13, a total of six plants (2,900 MW) had gone offline and ERCOT required consumers lower demand.⁴⁵
- Texas has boosted reserve margins through the addition of wind and solar generation, but NERC still considers ERCOT an elevated risk due to the potential of extreme weather and the ongoing drought.⁴⁶

MISO

- In its Seasonal Readiness Workshop Summer 2022, MISO projected a warmer-than-normal-summer and likely capacity shortfalls in June, July and August. MISO is forecasting in its Probable Generation Scenario a July peak at 124 GW, with 118.5 GW of probable generation available. According to MISO, emergency resources and non-firm energy imports will be needed to maintain system reliability.⁴⁷
- MISO's 2022/2023 Planning Resource Auction (PRA) further supports a capacity shortfall for the MISO North/Central Regions. Despite importing over 3,000 MW, MISO

⁴⁵ Mitchell Ferman, *Texas Grid Operator Told a Power Plant to Delay Repairs Ahead of a May Heat Wave. It Was Among Six Crashed*, Texas Tribune, May 17, 2022.

⁴⁶ North American Electric Reliability Corporation (NERC), *2022 Summer Reliability Assessment (SAS)*, May 2022.

⁴⁷ MISO, *Seasonal Readiness Workshop Summer 2022*, April 28, 2022.

may not be able to meet demand. The auction indicates MISO North/Central Regions have a slightly increased risk to implement temporary controlled load sheds.⁴⁸

SPP

- SPP anticipates sufficient resources to meet 2022 Summer Demand; however, NERC considers SPP an elevated risk in extreme weather events. NREC indicated the persistent drought in the Missouri River Basin could disrupt hydropower production and affect fossil units that use the river for heat rejection, which limit generator output - leading to energy shortfalls at peak demand periods. Above normal wind generation may provide some relief; however, this energy is not assured according to NERC.⁴⁹

A revision of EPA's budget-setting methodology is required to address this potential negative impact in reliability.

⁴⁸ MISO, *2022/2023 Planning Resource Auction (PRA) Results*, April 14, 2022.


⁴⁹ NERC, *SAS*, May 2022.

Appendix A: State Maps


Appendix A presents maps for the nine states evaluated, depicting the stations that - per EPA's analysis - are most affected by generation shifting. These maps denote in "red" those generating stations (per EPA) projected to reduce generation, while those projected to increase generation are depicted in "green". The magnitude of generation shifted (in terms of GWh) for each station is numerically summarized in parenthesis. For simplicity, only the sources most significantly affected are displayed - thus the generation "decrease" vs. "increase" as shown on each map will not balance.

Details are discussed in respective state summaries in section 8 of draft report


Arkansas: Major Generation Shifting Impact




Indiana: Major Generation Shifting Impact




Kentucky: Major Generation Shifting Impact




Missouri: Major Generation Shifting Impact




Ohio: Major Generation Shifting Impact




Pennsylvania: Major Generation Shifting Impact




Texas: Major Generation Shifting Impact



West Virginia: Major Generation Shifting Impact



Wyoming: Major Generation Shifting Impact



Appendix B: Summary of Planned Retirements- 2026-2030

	OPERATOR	Authority	STATE	LANT_ID	UNIT_NAME	GEN1	swNMPLT	STATUS	Changes/Retirement	DATE	TECHNOLOGY
1	XCEL	MISO	MN	6090	SHERBURNE COUNTY 1	1	660	OPR	PSC approved closure (2/8/22). Upper Midwest Resource Plan (6/25/21) to retire unit in 2026 to be replaced by four smaller gas facilities	2026	Coal Steam SCR Retrofit
2	AEP PSO	SWPP	OK	2963	NORTHEASTERN 3	3	473	OPR	Retire 2026	2026	Coal Steam SCR Retrofit
3	VISTRA ENERGY (DYNEGY MIDWEST (IPH))	MISO	IL	6017	NEWTON 1	1	617.4	OPR	To be retired at the end of 2027 (9/29/20).	2027	Coal Steam SCR Retrofit
4	CLECO (merger with Macquarie)	MISO	LA	6190	RODEMACHER 2 (Brame Energy Center 2)	2	558	OPR	2020 IRP recommends LUS to consider retirement at the end of 2027.	2027	Coal Steam SCR Retrofit
5	SOUTHERN-MSPC	SERC	MS	6073	VJ DANIEL 2	2	548.3	OPR	MPC in its 2021 IRP will own 100 percent of one unit and retire it December 31, 2027.	2027	Coal Steam SCR Retrofit
6	VISTRA ENERGY (DYNEGY)	ERCO	TX	6178	COLETO CREEK 1	1	622.4	OPR	To be retired in 2027 due to economic pressure and environmental regulations.	2027	Coal Steam SCR Retrofit
7	PACIFICORP	WEST	WY	4158	DAVE JOHNSTON 1	1	133.6	OPR	retire in 2027.	2027	Coal Steam SCR Retrofit
8	PACIFICORP	WEST	WY	4158	DAVE JOHNSTON 2	2	133.6	OPR	retire in 2027.	2027	Coal Steam SCR Retrofit
9	PACIFICORP	WEST	WY	4158	DAVE JOHNSTON 3	3	255.0	OPR	retire in 2027.	2027	Coal Steam SCR Retrofit
10	PACIFICORP	WEST	WY	4158	DAVE JOHNSTON 4	4	400.0	OPR	retire in 2027.	2027	Coal Steam SCR Retrofit
11	SOUTHERN-ALPC	SERC	AL	3	BARRY 4	4	403.7	OPR	Order on HCI violation(1/3/22). Repowered to fire natural gas during peak loads by 2028 due to ELG.	2028	Coal Steam SCR Retrofit
12	ENTERGY	MISO	AR	6009	WHITE BLUFF 1	1	900	OPR	Both units cease burning coal as of 12/31/2028. Also reached an agreement with Sierra Club & NPCA on the same dates, which was	2028	Coal Steam SCR Retrofit
13	ENTERGY	MISO	AR	6009	WHITE BLUFF 2	2	900	OPR	Both units cease burning coal as of 12/31/2028. Also reached an agreement with Sierra Club & NPCA on the same dates, which was	2028	Coal Steam SCR Retrofit
14	LGE-KU(PP&L)	SERC	KY	1364	MILL CREEK (KY) 2	2	355.5	OPR	(11/25/20).	2028	Coal Steam SCR Retrofit
15	DTE ENERGY	MISO	MI	6034	BELLE RIVER 1	ST1	697.5	OPR	Announced the end of all coal use no later than December 2028, action complies with ELG (10/13/21).	2028	Coal Steam SCR Retrofit
16	DTE ENERGY	MISO	MI	6034	BELLE RIVER 2	ST2	697.5	OPR	Announced the end of all coal use no later than December 2028, action complies with ELG (10/13/21).	2028	Coal Steam SCR Retrofit
17	AMEREN-UE	MISO	MO	2107	SIOUX 1	1	549.7	OPR	2020 IRP - To be retired in 2028	2028	Coal Steam SCR Retrofit
18	AMEREN-UE	MISO	MO	2107	SIOUX 2	2	549.7	OPR	2020 IRP - To be retired in 2028	2028	Coal Steam SCR Retrofit
19	AEP - SWEPCO	SWPP	TX	6139	WELSH 1	1	558	OPR	June 2022 Investor Meetings - Retirement in 2028	2028	Coal Steam SCR Retrofit
20	AEP - SWEPCO	SWPP	TX	6139	WELSH 3	3	558	OPR	June 2022 Investor Meetings - Retirement in 2028	2028	Coal Steam SCR Retrofit
21	ENTERGY	MISO	AR	6641	INDEPENDENCE 1	1	900	OPR	Reached an agreement with Sierra Club and NPCA to cease burning coal by December 31, 2030, which was approved by a Federal judge on March	2030	Coal Steam SCR Retrofit
22	ENTERGY	MISO	AR	6641	INDEPENDENCE 2	2	900	OPR	Reached an agreement with Sierra Club and NPCA to cease burning coal by December 31, 2030, which was approved by a Federal judge on March	2030	Coal Steam SCR Retrofit
23	NRG	PJM	IL	879	POWERTON 5	5	892.8	OPR	Clean Engery Bill (SB2408) signed to close no later than January 1, 2030.	2030	Coal Steam SCR Retrofit
24	NRG	PJM	IL	879	POWERTON 6	6	892.8	OPR	Clean Engery Bill (SB2408) signed to close no later than January 1, 2030.	2030	Coal Steam SCR Retrofit
25	ENTERGY	MISO	LA	1393	RS NELSON 6	6	614.6	OPR	ENTERGY to retire all coal by 2030 (2/24/21).	2030	Coal Steam SCR Retrofit
26	XCEL	MISO	MN	6090	SHERBURNE COUNTY 3	3	809	OPR	to close in 2030	2030	Coal Steam SCR Retrofit
27	NRG ENERGY	ERCO	TX	298	LIMESTONE 1	1	893	OPR	2017	2030	Coal Steam SCR Retrofit
28	NRG ENERGY	ERCO	TX	298	LIMESTONE 2	2	813.4	OPR	2017	2030	Coal Steam SCR Retrofit
29	DESERT	WEST	UT	7790	BONANZA 1	1	499.5	OPR	consumption and installing new LNB/OFA. Could retire when the 20 million limit is reached.	2030	Coal Steam SCR Retrofit